



Ref no. 9397/CREDA/SPVPP/2022-23

Dated 10/08/2022

TENDER ADDENDUM NOTICE

It has been observed from our past experience that **Low Maintenance Lead Acid batteries (LMLA)** is not being maintained by the system integrators throughout the five years warranty period. The system integrators always refuse to repair/replace the faulty batteries stating that the failure is due to operational abuse or improper maintenance or due to manufacturing defects hence the following points is hereby added in continuation of the **Section 01, Page no 16-17, Clause no. 22 "Comprehensive Maintenance Contract (CMC)"** of e-bid document no. **105486/CREDA/SPVPP/2022-23 dated 29.07.2022:-**

- g. The bidder has to deploy efficient man power for the five years routine maintenance of **LMLA batteries**. Bidder should have to visit the plant in each quarter for routine maintenance and topping up of batteries. The report of the routine maintenance and distilled water topping has to be submitted on quarterly basis to concerned District office of CREDA along with the geo-tagged photograph of maintenance work performed.
- h. In case of any complaint received regarding poor performance/fault of **LMLA batteries** from the field offices of CREDA then the bidders shall have to replace the batteries with new batteries within 24 hrs after the receipt of information through any means i.e. Email, letter, telephone etc. No repair work shall be allowed or permitted in this regard. If bidder fails to do so CREDA will replace the **LMLA batteries** from their risk and cost.
- i. In continuation of point "h", the bidder shall be sole responsible for all warranty compliances and he cannot shift his responsibility to vendor/manufacturer of **LMLA batteries**, if he does then penal action will be taken against him as per tender terms and conditions.
- j. The bidders shall have to quote their rates for the SPVPP with **LMLA battery bank** considering the above maintenance clause i.e. point no. g, h & i.

Note:-

1. The Bidders are requested to take note of the following changes made in the tender documents, which are to be taken in to account while submitting the tender. They shall be presumed to have done so and accordingly submitted the tender.
2. All other specifications, terms and conditions of the original tender document shall remain unchanged.
3. This addendum notice shall be the part of the tender documents and becomes effective immediately.

(Sanjeev Jha)

Chief Engineer(RE-05)

Tender Cell ,CREDA HO Raipur