



Chhattisgarh State Renewable Energy Development Agency (CREDA)

(Dept. of Energy, Govt. of Chhattisgarh)

Near Energy Education Park, Village Fundhar

VIP (Air Port Road) Raipur 492015 (C.G.)

Ph.: +91-8770580522, 9916861794

E-mail: credatendercell@gmail.com, Website: www.creda.co.in

BID DOCUMENT No.82244/CREDA/HOR/RE-V/GCRT/2021 Date.-27-08-2021

“FOR DESIGN, SUPPLY, INSTALLATION AND COMMISSIONING WITH 5 YEARS COMPREHENSIVE MAINTENANCE OF GRID CONNECTED SOLAR PHOTOVOLTAIC POWER PLANT OF DIFFERENT CAPACITIES AT THREE DIFFERENT LOCATIONS IN CHHATTISGARH STATE.

- 1) Sihawa & Mahamaya Bhawan Building in Pt. Sunder Lal Sharma Open University, Birkona, Bilaspur. (200kWp)
- 2) Old Building District and Session Court, Raigarh. (30kWp)
- 3) New Building District and Session Court, Raigarh. (20kWp)

Particulars	From Date & Time	To Date & Time	Place
Date of issue of notice inviting bid	27-08-2021 05:00 pm	----	-----
Period of availability of bidding document at website	27-08-2021 05:00 pm	27-09-2021 05:00 pm	www.creda.co.in/Tenders https://eproc.cgstate.gov.in
Submission of queries in writing	06-09-2021 11:00 am	06-09-2021 05:00 pm	CREDA, HO, Raipur
Submission of Online Bid (Technical + e-Price Bid)	27-08-2021 05:00 pm	27-09-2021 02:00 pm	https://eproc.cgstate.gov.in
Opening of Technical Bid	27-09-2021 03:00 pm	27-09-2021 05:00 pm	At CREDA, Conference Hall HO (RE-II) Raipur
Opening of e-Price Bid	After conclusion of Technical evaluation and declaration of eligible bidders		At CREDA, Conference Hall HO (RE-II) Raipur

Bid Document Cost –Rs.5000.00 + 18% GST = Rs.5900.00/-(In words Rupees Five Thousand Nine Hundred Rupees Only) to be deposited in CREDA’s account along with EMD via RTGS/NEFT as a single transaction.

Document can also be downloaded from our website www.creda.co.in or from Chhattisgarh e-Procurement portal i.e, <https://eproc.cgstate.gov.in> .

CHATTISGARH STATE RENEWABLE ENERGY DEVELOPMENT AGENCY

CONTENTS

Section	Description	Page No.
	Cover Page, Contents etc.	1-2
	Notice Inviting Tender	3
	Check List,	5
	Details of EMD and Tender Document Fee	6
	Undertaking of the Bidder	7
Section-01	Instruction For Bidder	8-11
	Eligibility Criteria & Bidding process	8-9
	EMD & Bid Document Fee /Submission of Documents/Specific Amendments/GST&PAN/Validity etc.	9
	Bid Document Fee /Technical Criteria /Jurisdiction etc.	10-11
Section -02	General Condition of Contract	12-18
	Definitions/Contract Document/Manner of execution	12-13
	Variations, Additions & Omissions/Inspection/Completion work/ Eligible Bidder Default Liability/ Force Majeure/Rejection of works	13-14
	Terms of Payment/ Security deposit/ Non Assignments etc	15-16
	Declaration of conflict of Interest/Bid Evaluation/evaluation of Price Bid	17-18
Section-03	Scope of work	19
Section-04	Technical specification	20-38
	Annexure-“A” (I & II) (Monthly Comprehensive Maintenance Report Format)	39-43
Section-05	e-price Bid/Draft Agreement/Schedules and Annexures	44-54
	e-Price Bid (Supply, Installation & Commissioning of Grid Connected Rooftop Solar Power Plants)	44
	Annexure-I Draft Agreement	45-47
	Schedule - I Part-A	48
	Schedule - II Part-B	49
	Schedule - III Part-C	50
	Annexure – II Format for Affidavit for Conflict of Interest	51-52
	Annexure- III Benchmark cost for Grid-connected Rooftop Solar	53
	Annexure- IV Undertaking from system Integrator for Registration	54

Ref. No.8723/CREDA/HOR/RE-V/GCRT/2021-22

Date.27-08-2021

NOTICE INVITING TENDER

CREDA invites online Bids for “Design, Supply, Installation and Commissioning with 5 years Comprehensive Maintenance of Grid Connected Solar Photovoltaic Power Plant of different capacities at three different locations in Chhattisgarh” from registered System Integrator having experience in the field of Design, Supply, Installation, Testing and Commissioning of Grid Connected Solar Photovoltaic Power Plants, details as per following -

Sl.No.	Item Description	Approximate value of work (In ₹)	Cost of Bid Document (In ₹)	EMD (In ₹)	Essentials
1	“Design, Supply, Installation and Commissioning with 5 years comprehensive maintenance of Grid Connected Solar Power plant having capacity 200KWp at Sihawa & Mahamaya Bhawan Building in Pt. Sunder Lal Sharma Open University, Birkona, Bilaspur.	₹ 72.00 Lakhs	₹ 5000.00 +18% GST = ₹ 5900.00	₹ 1,44,000.00	As per clause no. 1A to 1G of Eligibility Criteria (Page no.8)
2	“Design, Supply, Installation and Commissioning with 5 years comprehensive maintenance of Grid Connected Solar Power plant having capacity 30KWp in Old Building District & Session Court, Raigarh.	₹ 11.40 Lakhs		₹ 22,800.00	
3	“Design, Supply, Installation and Commissioning with 5 years comprehensive maintenance of Grid Connected Solar Power plant having capacity 20KWp in New Building District & Session Court, Raigarh.	₹ 07.60 Lakhs		₹ 19,000.00	
TOTAL		₹ 91.00 Lakhs	₹ 5,900 /-	₹ 1,85,800/-	

Important Events and time schedule for this Bid are as follows –

Particulars	From Date & Time	To Date & Time	Place
Date of issue of notice inviting bid	27-08-2021 05:00 pm	----	----
Period of availability of bidding document at website	27-08-2021 05:00 pm	27-09-2021 05:00 pm	www.creda.co.in ; https://eproc.cgstate.gov.in
Submission of queries in writing	06-09-2021 11:00 am	06-09-2021 05:00 pm	CREDA, HO, Raipur
Submission of Online Bid (Technical + e Price Bid)	27-08-2021 05:00 pm	27-09-2021 02:00 pm	https://eproc.cgstate.gov.in
Opening of Technical Bid	27-09-2021 03:00 pm	27-09-2021 05:00 pm	At CREDA, Conference Hall HO (RE-II) Raipur
Opening of e-Price Bid	After conclusion of Technical evaluation and declaration of eligible bidders		At CREDA, Conference Hall HO (RE-II) Raipur

Technical bid and Price Bid shall be submitted in online only at <https://www.eproc.cgstate.gov.in>. Bidders are advised to follow the instructions provided for Registration and e-Submission Process accordingly. (For any query about e-bidding please visit user manual at <https://www.eproc.cgstate.gov.in>)

Details of this Bid are mentioned at Bid Documents which can be downloaded from our website www.creda.co.in. The Bidder should have to deposit Bid document cost along with EMD as mentioned above through NEFT/RTGS in the account of CREDA mentioned below.

Bidders are requested to submit Pre-Bid queries with their suggestions/objections/ reservations if any with details so as to avoid any confusion and to ensure clarity and transparency regarding the Bid.

CREDA reserves all rights to accept/reject any or all Bids in full/part without assigning any reasons. Any amendment in tender documents shall only be notified through the website of CREDA www.creda.co.in

**Chief Engineer
RE-V, H.O.
CREDA
Raipur (CG)**

A. Details of Beneficiary/ Account Holder

Name of Beneficiary	Chhattisgarh State Renewable Energy Development Agency (CREDA)
Address	Near Energy Education Park, VIP Road (Airport Road), Raipur
Contact Number	Tel.: 9425562821

B. Bank Details

Bank Name	ICICI Bank
Branch Address	Pachpedi Naka, Raipur
Beneficiary Account No.	134601000400
Beneficiary Account Name	C G ST Renewable Energy Dev. Agency (CREDA)
Type of Bank Account	Saving
MICR Code of the Bank	492229006
IFSC Code of the Bank	ICIC0001346

CHECK LIST OF DOCUMENTS TO BE UPLOADED IN THE E-BIDDING PORTAL

To ensure that your Tender/Bid uploaded on the Chhattisgarh e-Procurement portal i.e. <https://eproc.cgstate.gov.in> is complete in all respects, please go through the following checklist & tick mark for the enclosures attached with your Tender/Bid –

Sl. No.	Envelope	Description	Complied (For Office Use Only)
1.	A. Pre-Qualification	Earnest Money Deposit EMD + Tender Document Fee submission form of the bidder confirmed by CREDA (as on page-6)	
2.		Self-Attested Undertaking of the Bidder as mentioned on Page – 7 of the tender document	
3.		Copy of original tender document duly signed & with stamp on each page, as a confirmation of acceptance of Terms & Conditions (T&C).	
4.		PAN, GSTIN issued in the name of the Bidder	
5.		Self-certificate from Bidder on not being a debarred from Government contract or a blacklisted company.	
6.		Declaration of conflict of interest - by bidder about any relatives working with CREDA and Affidavit as per Annexure - II	
7.		Copy of Registration: Certificate (or Acknowledgment) as System Integrator of CREDA in SPV Programme valid for FY 2021-22 or undertaking from System Integrator for Registration (as per Annexure-IV).	
8.	B. Technical and Financial-Qualification	Original Net Worth Certificate duly signed by Chartered Accountant	
9.		Copy of Certificate for last three consecutive year's turnover of works done regarding SPV Projects.	
10.		Copy of ITRs for last three Financial Years of the Bidder	
11.		Technical details and specifications highlighting salient features of the systems and latest test report etc.	
12.		Completion and Performance Certificates of Supply, Installation & Commissioning work of Grid Connected Solar Power Plants in Bidder name in State/Central Govt/SNA. Scheme for any three consecutive Years(i.e. FY 2017-18,2018-19,2019-20/2020-21)	
13.		Forwarding Letter & Undertaking by the Bidder	
14.		Schedule – I Part-A	
15.		Schedule – II Part-B	
16.		Schedule – III Part-C	

Details of EMD and Tender Document Fee

A scanned copy of the EMD and Tender Document fee transaction shall have to be uploaded in the format below on the Chhattisgarh e-Procurement portal. Details uploaded in incorrect format shall be rejected.

Tender No. and Date	
Name of the Bidder	
Bidder's Bank Account Details	
(i) Name of the bank	
(ii) Branch	
(iii) IFSCCode	
(iv) Account No.	
(v) Transaction reference number	
(vi) Date of transaction	
(vii) EMD + Bid Document Fee	(Rs.+ Rs. 5,900) Total In Rs./- Total In Words -(.....)

Name of A/c	CREDA
Bank & Branch Name	ICICI Bank, Pachpedi Naka, Raipur
Bank Account Number	134601000400
Branch IFSC Code	ICIC0001346

(Sign & Seal of the bidder)

***NOTE –**

1. The EMD and the Tender Document Fee shall have to be deposited as a single NEFT/RTGS transaction in CREDA's bank account (amount mentioned above).

UNDERTAKING OF THE BIDDER

I/We have visited the site prior to submission of the bid documents and found that following sites are clear and suitable for installation and also inspected the probable terminating point of Grid Synchronization.

1) Sihawa & Mahamaya Bhawan Building in Pt. Sunder Lal Sharma Open University, Birkona, Bilaspur, Chhattisgarh (200 Kwp).

2) Old Building District and Session Court Raigarh (30kWp).

3) New Building District and Session Court Raigarh (20kWp).

I/We have read carefully and examined the notice inviting tender, schedule, General Rules and terms and conditions of the contract, special conditions, Schedule of Rates and other documents and Rules referred to in the Bid document for the supply.

I/We hereby Bid my rates for the execution of the work for CREDA as specified within the time stipulated in the schedule in accordance with all aspects with the specifications, designs, drawings and instructions with such conditions so far as applicable.

I/We agree to keep the Bid valid for **One Hundred Eighty (180) days** from the due date of submission thereof and not to make any modifications in its terms and conditions.

A sum of **Rs.....** is hereby forwarded as **Earnest Money** in the form of RTGS / NEFT payable to CREDA at Raipur (C.G.). If I/We, fail to commence or complete the Work Ordered in specified time or fail to fulfill any condition of Tender document, I/We agree that the CREDA shall, without prejudice to any other right or remedy, be at liberty to forfeit the said Earnest Money absolutely. The said Earnest Money shall be retained by CREDA towards security deposit to execute all the works referred to in the Bid documents upon the terms and conditions contained or referred to therein and to carry out such deviations as may be required by CREDA.

I/We hereby declare that I/We shall treat the tender documents, specifications and other records connected with the work as secret/confidential and shall not communicate information derived there from to any person other than a person to whom I/We have authorized to communicate the same or use the information in any manner prejudicial to the safety of CREDA/Government.

I/We shall abide to all the laws and shall be responsible for making payments of all the taxes, duties, levies and other Govt. dues etc. to the appropriate Govt. departments. I declare that none of my relative is working in CREDA as employee. I also declare that all the material/items to be used by me in Supply, Installation & Commissioning works of Solar Power plants and other related works are allotted under this tender shall be indigenous.

Our GST Registration No. The PAN No. under the Income Tax Act is

I/We shall be responsible for the payment of the respective taxes to the appropriate authorities and should I/we fail to do so, I/we hereby authorize CREDA to recover the taxes due from us and deposit the same with the appropriate authorities on their demand.

I/We hereby state that we have provided information of our near relatives as stated in the affidavit attached at “Annexure – II”

Dated:

Signature

Place:

Name of Bidder with seal

Witness :

Signature:

Name:

Postal Address:

.....

SECTION – 1

INSTRUCTIONS FOR BIDDERS

1. **ELIGIBILITY CRITERIA :**

- A. Bidders should be registered in CREDA as a System Integrator in “B” or “C” Category, in SPV Programme for the financial year 2021-22. In case the bidder is eligible with respect to the eligibility criteria as mentioned in S.No.1 (B) below and is not registered as System Integrator in CREDA in “B” or “C” Category then such bidder shall have to get themselves register if they win the bid, before award of Letter of Intent (LOI) to them. Bidder should be aware of the terms & conditions of getting registered in CREDA as System Integrator in “B” or “C” category. Hence if the successful bidder does not fulfill the eligibility of such registration then such bidder will be rejected & their EMD will be forfeited.
- B. Bidder should have minimum direct experience of Supply, Installation and Commissioning of minimum **05 Nos.** Grid Connected Roof Top Solar Power Plants of minimum aggregate capacity of **300 KW** on CREDA Mode/Market Mode in Chhattisgarh or any other state within India through State Nodal Agencies of MNRE or SECI or Govt. Organization. Satisfactorily completion certificate issued by Govt/ Govt Undertaking/SNA/SECI shall only be considered for any three consecutive years (i.e FY 2017-18, 2018-19, 2019-20/ 2020-21).
- C. Bidder must have minimum **Net worth of Rs. 5.00 Lacs as on 31st March 2020 (which is defined as “Net value of the Assets minus (-) Net value of liabilities”)**. They shall have to submit a Certificate duly signed by a qualified and registered Chartered Accountant having UDI number as a proof. Produced certificate must tally with the audited balance sheet.
- D. Bidder should have an aggregate turnover of minimum **Rs. 2.00 Crore** in any three consecutive year’s i.e.2017-18, 2018-19, 2019-20 / 2020-21 in SPV Projects. Certified copies of the annual returns and audited balance sheet submitted to the Registrar of Companies/ Income Tax Authorities should be enclosed. For the preceding years a **Certified Summarized Sheet** of turnover certified by registered CA must be enclosed.
- E. Bidder will have to submit a copy of relevant test reports from MNRE approved test labs for SPV Modules/Inverters, if they win the bid.
- F. Bidder who is debarred from business by Govt. /Govt. Agency in any state would not be eligible to participate in this bid. A self-declaration should be submitted by the bidder to this effect, failing which bid shall be rejected.
- G. **Additional Eligibility Criteria-** Even though the bidders meet the above qualifying criteria, they are subject to be disqualified if they have:
 - a. Made misleading or false representations in the forms, statements, affidavits and attachments submitted in proof of the qualification requirements; and/or
 - b. Record of poor performance such as abandoning the works, not properly completing the contract, inordinate delays in completion litigation history, or financial failures etc.; and/or
 - c. Participated in the previous bidding for the same work and had quoted unreasonably high or low bid prices and could not furnish rational justification for it to CREDA.

2. **CONSORTIUM-** Consortium of bidders shall not be allowed in this tender.

3. **START-UP/NEW ENTREPRENEUR-** Start-up/New Entrepreneur shall not be allowed in this tender.

4. **BIDDING PROCESS -**

For ease of accessing the e-bidding website and registration the following is to be done by bidder -

- A. Visit <https://eproc.cgstate.gov.in>
- B. **Prospective bidders are requested to download, read and understand the Manuals present on the website so as to clearly understand the bid submission process.**

- C. The user will be directed to e-bidding page where all information regarding registration is available along with helpline details.
- D. Technical bid and Price Bid shall be submitted online only at <https://eproc.cgstate.gov.in> latest by **02.00 PM on 27-09-2021**. Bids submitted after scheduled time and date shall not be considered.

5. EMD & DOCUMENT FEE -

The EMD and tender Document Fee shall have to be paid via RTGS/NEFT to CREDA's Account mentioned below as a single transaction.

Name of the A/c	CREDA
Bank & Branch Name	ICICI Bank, Pachpedi Naka, Raipur
Bank Account Number	134601000400
Branch IFSC Code	ICIC0001346

6. SUBMISSION OF DOCUMENTS -

All the documents including technical and financial Bid should be submitted online on Chhattisgarh e-Procurement portal <https://eproc.cgstate.gov.in> as per the items mentioned in the checklist on page no. 5 in this bid.

7. SPECIFICATION AMENDMENTS -

The Specifications of items should be as per specified in the Bid. If any amendments are issued by MNRE/CREDA in due course of time, in this context, then those shall be applicable under this tender.

8. GST & PAN -

Bidder shall have to submit copies of GST registration number and PAN numbers issued by the appropriate authority.

9. THE BID -

The Pre-Qualification, Technical-Financial Qualification Documents and Price Bid, other related documents must be uploaded in the portal i.e. <https://eproc.cgstate.gov.in> from **05:00 PM 27-08-2021 to 02:00 PM dated 27-09-2021**. Nobody is authorized to receive or grant receipt for Bid delivered on behalf of CREDA. **Bid received through any other means shall not be considered and shall be rejected..**

10. ANALYSIS OF RATE -

Bidder should note that this is site specific bid hence should quote their rates considering variation of site conditions, variation in price of different components, connectivity of Solar System, Synchronization of complete Solar Power Plant connectivity to bidirectional energy meter and also keeping the quantum & quality of work in mind. If CREDA anticipates that rate is abnormally low or high, CREDA shall have liberty to amend the rates or reject the bid.

11. REGISTRATION OF BIDDER -

Bidders who are not registered with CREDA, upon allocation of work shall register himself as system integrator of CREDA before execution of agreement failing which work allocation shall stand cancelled without any further notice in this regard and allocation work shall be re-allocated to other parties as per tender condition.

12. VALIDITY -

Full descriptive particulars and complete specifications should accompany the offer. Offers should be kept open for acceptance for at least **180 days** from the date of opening. After finalization of this tender the approved rates shall be valid till one year from the date of finalization; however CREDA shall have liberty to increase or decrease this validity if needed.

13. TERMS & CONDITIONS -

- A. The terms, conditions and specifications mentioned in tender document shall be binding on the bidders and no condition or stipulation contrary to the conditions shall be acceptable. It may please be noted that the bidders who do not accept terms and conditions stipulated in this tender documents, their offers shall be liable to be rejected out-rightly without assigning any reason whatsoever.
- B. Each page of tender document & enclosures shall be signed by the bidder and seal affixed. All the pages of the documents issued must be uploaded along with the technical offer. In case of any corrections/alterations in the tender, the bidder should attest the same; otherwise tenders **will get rejected**.
- C. Bidders are also instructed to check each and every item and upload the documents as applicable and required to be uploaded on the bidding portal. Incomplete tender submission may result in rejection of the entire tender.

14. CREDA RESERVES THE RIGHT -

To reject or accept any or all Bids fully or partly without assigning any reason on the grounds considered advantageous to CREDA, whether it is the lowest Bid or not.

15. COMMUNICATIONS -

- A. All the communication between Bidder and CREDA shall be in writing. Notice sent by Fax or other Electronic means shall be effective on confirmation of the transmission. Notice sent by registered post or speed post shall be effective of delivery or at expiry of normal delivery period as under taken by Postal Service.
- B. Offers through Telegraph/Fax/Emails/Post/Courier or open offers etc. received shall be summarily rejected.

16. TENDER DOCUMENT FEE AND EARNEST MONEY-

Each bidder should submit Tender Document Fee and Earnest Money Deposit (EMD) in the form of RTGS/NEFT as single transaction only as mentioned in the NIT vide No.8723/CREDA/HOR/RE-V/GCRT/2021-22 Dated.27-08-2021 in this tender. Tender Document Fee & EMD submitted in any other form e.g. **Bank Guarantee/FDR /TDR etc. shall not be accepted.**

17. PRE-BID SUBMISSION OF QUERIES -

- A. All suggestions, doubts, confusion, request, queries etc., shall have to be submitted to CREDA in writing before **06.09.2021 till 05:00 PM**. After that any representation in this regard shall not be considered. The purpose of the pre-bid queries is to clarify issues regarding this tender that can be raised at that stage.
- B. Amendments/clarifications, if any arising during pre-bid meet, shall be uploaded on www.creda.co.in and on the Chhattisgarh e-Procurement portal

18. TECHNICAL CRITERIA -

Bidder shall have to give a self declaration that Grid Connected Solar Power Plant & its components are confirming to the latest MNRE/CREDA specifications & IS standards.

19. FORFEITURE OF EARNEST MONEY DEPOSIT -

It should be clearly understood that in the event of bidder failing to enter into the agreement in the prescribed format on their quoted rates and also fails to execute assigned works under any Scheme of CREDA, within stipulated time, if he is so communicated within the validity period of the offer, the full amount of earnest money will be forfeited and bidder shall be debarred from future business with CREDA. CREDA's decision in this regard will be final and binding on the bidders.

20. PRICE OF WORK -

- A. The Price quoted for all work must be with 5 years system warranty and comprehensive maintenance. The GST shall be included with price quoted. The prices shall be filled exactly as per **Price Bid enclosed**.
- B. Any change in GST shall be become applicable during the period of contract.
- C. In this regard if there is any change in the composition ratio of goods and services by any Authority/ Courts, same shall be applicable.

21. ENGINEERING DOCUMENT -

Bidders shall have to submit Engineering Documents with technical details, drawings Specifications of components and make etc. to CREDA for approval, as and when asked by CREDA. Works may only be started out only after approval of the Engineering Document/Drawing.

22. INSPECTIONS -

CREDA reserves the rights to inspect the material at Godowns /Temporary Stores before dispatch and also at works sites.

23. MANDATORY DEDUCTION -

One Percentage of the cost of installation of **Power Plant** including civil work will be deducted from the Payment and will be deposited in the account of CHHATTISGARH BHAWAN EVAM ANYA SANNIRMAN KARMKAR MANDAL. The bidder shall have to provide list of labours/manpower engaged for the execution of work to the Engineer-in-charge of CREDA. (As per CG Govt.'s Notification 1996)

24. MANDATORY EMPLOYMENT -

Qualified diploma engineer with minimum wage rupees 15000/- per month for works above rupees 20 lacs and Qualified graduate engineer with minimum wage rupees 25000/- per month for works above rupees 01 crore shall have to be deployed by the System Integrator. (As per CG Govt.'s order no. F7-17/2020/1-6 Dated 02.12.2020).

25. TAX OBLIGATIONS -

CREDA shall deduct TDS for Income Tax, applicable cess on Civil Work etc. under various acts and deposited with the appropriate authority. Costs and taxes before execution of agreement with CREDA so as to ensure tax deposition as per Government Rules accordingly.

26. JURISDICTION OF THE COURT -

Any dispute arising out of the contract shall be subject to the jurisdiction of Hon'ble High Court of Chhattisgarh.

27. CORRUPT OR FRAUDULENT PRACTICES -

- A. CREDA requires the bidder to strictly observe the laws against fraud and corruption in force in India, namely, Prevention of Corruption Act, 1988.
- B. It is required that each bidder (including their respective officers, employees and sub-contractors) adhere to the highest ethical standards, and report to the Government/ Department all suspected acts of fraud or corruption or coercion or collusion of which it has knowledge or become aware, during the tendering process and throughout the negotiation or award of contract.

SECTION - 2

GENERAL CONDITIONS OF CONTRACT

1. DEFINITIONS -

In writing General Conditions of Contract, the specifications and bill of quantity, the following words shall have the meanings hereby indicated, unless there is something in the subject matter or content inconsistent with the subject.

- CREDA shall mean the Chhattisgarh State Renewable Energy Development Agency represented through the Chief Engineer.
- Work shall mean any work entrusted to the bidder as mentioned in the scope of work and Work Order.
- The "Engineer in charge" shall mean the Engineer or Engineers authorized by CREDA for the purpose of this contract. Inspecting Authority shall mean any Engineering person or personnel authorized by CREDA to supervise and inspect the solar power plant installation Work.
- "The Eligible SI/Bidder" shall mean the Bidder awarded with the contract or their successors and permitted assigns. Contract Price shall mean the sum named in or calculated in accordance with the provisions of the contract as the contract price. General Conditions shall mean the General conditions of Contract.
- "Specifications" shall mean the specifications annexed to these General Conditions of contract and shall include the schedules and drawings attached thereto or issued to the eligible bidder from time to time, as well as all samples and pattern, if any,
- "Month" shall mean calendar month. "Writing" shall include any manuscript, typewritten, printed or other statement reproduced in any visible form whether under seal or written by hand.

2. CONTRACT DOCUMENT -

The term "Contract" shall mean and include the General conditions, specifications, schedules, drawings and Work Orders etc., issued against the contract schedule of price or their final general conditions, any special conditions applying to the particular contract specification and drawings and agreement to be entered into. Terms and conditions not herein defined shall have the same meaning as are assigned to them in the Indian contract Act or any other Act in vogue or by any person of common knowledge and prudence.

3. MANNER OF EXECUTION -

Execution of work shall be carried out in an approved manner as outlined in the technical specifications or where not outlined, in accordance with desired Specifications laid down by CREDA, to the reasonable satisfaction of the Engineer.

- i) The eligible bidder shall conduct a detailed survey of site and submit Site Clearance and necessary documents and survey details through concerned District/Regional Office of CREDA in prescribed manner.
- ii) District/Regional Office CREDA shall examine these reports and after satisfaction, forward these to Chief Engineer in-charge of SPV Grid Connected Project in Head Office of CREDA, Raipur for approval.
- iii) The Bidder shall start work within 15 days after the date of issue of work Order. Work order will be given to the eligible Bidder only after execution of the agreement with CREDA.
- iv) All the materials required for the installation of SPV Power Plant as per Work Order issued shall be kept at site in the custody of the eligible bidder. CREDA or the beneficiary shall not be responsible for any loss or damage of any material during the installation.
- v) All the electrical works should be done as per Indian Electricity Act. The persons engaged for carrying out electrical works should have a valid license of A Class Electrical Contractor.
- vi) After installation, joint inspection will be done in presence of beneficiary, authorized

representative of bidder and concerned CREDA officials. After successful commissioning of SPV Power Plant and its approval from CREDA, a JCC will be signed and the payment claim will be forwarded for payments as per guidelines and procedures of CREDA.

4. VARIATIONS, ADDITIONS & OMISSIONS -

CREDA shall have the right to alter, amend, omit, split or otherwise vary the quantum of work, by notice in writing to the Bidder. The eligible Bidder shall carry out such variation in accordance with the rates specified in the contract so far as they may apply and where such rates are not available; those will be mutually agreed between CREDA and the eligible Bidder.

5. INSPECTION -

- A. The Engineer-in-Charge or his authorized representative(s) shall be entitled at all reasonable times to inspect and supervise and test during supply and commissioning. Such inspection will not relieve the eligible bidder from their obligations under this contract.
- B. Material can be inspected before dispatch or in transit by the authorized representatives of CREDA at the factory / godown at the cost of the eligible bidder, if desired by CREDA.
- C. CREDA will undertake real time performance and quality test of randomly selected items and its components during the course of execution as per the specifications and guidelines laid by CREDA to ensure quality items/work.

6. COMPLETION OF WORK -

Time being the essence of contract, the installation of the SPV Power Plant shall be completed within the time schedule prescribed in the Work Order.

7. ELIGIBLE BIDDER'S DEFAULT LIABILITY -

CREDA may by written notice of default to the eligible SI, terminate the contract in circumstances detailed hereunder -

- (a) If in the opinion of the CREDA, the eligible bidder fails to complete the work within the time specified in the work Order or within the period for which extension has been granted by CREDA to the eligible bidder.
- (b) If in the opinion of CREDA, the eligible bidder fails to comply with any of the provisions of this contract.
- (c) In the event of CREDA terminating the contract in whole or in part as provided in paragraph (a) above, CREDA reserves the right to engage another eligible SI or agency upon such terms and in such a manner as it may deem appropriate and the eligible bidder shall be liable to CREDA for any additional costs or any losses caused to CREDA as may be required for the supply of the Items and or for penalty as defined under this tender document until such reasonable time as may be required for the final completion of the work.
- (d) In the event CREDA does not terminate the contract as provided in paragraph (a) the eligible bidder shall continue performance of the contract, in which case he shall be liable to CREDA for penalty for delay as set out in this Bid document until the work is completed.

8. FORCE MAJEURE -

The eligible bidder shall not be liable for any penalty for delay or for failure to perform the contract for reasons of FORCE MAJEURE such as act of God, acts of public, enemy, LWE problems, acts of government, cyclone, fires, floods, epidemics, quarantine restrictions, strikes, freight embargoes provided that if bidder shall submit delay notice with appropriate cause of delay to the CREDA in writing within **15 days** of force majeure. CREDA shall verify the facts and may grant such extension as facts justify. Delay in supply of any accessories of items etc. by the related vendors, to whom the Bidder has placed order, shall also not be treated as force majeure.

9. REJECTION OF WORKS -

In the event of any of the material supplied/work done by the eligible bidder is found defective in material or workmanship or otherwise not in conformity with the requirements of this contract specifications, CREDA shall either reject the material and/or work and advise the eligible bidder to rectify the same. **CREDA may impose penalty for such rejection up to 200% cost of the**

entire system. Habitual/repeated offenders shall be black listed/debarred to participate in the any Tender/ Activity of CREDA till further orders. The eligible bidder on receipt of such notices shall rectify or replace the defective material and rectify the work free of cost. If the eligible bidder fails to do so CREDA may -

- a) At its option replace or rectify such defective materials and/or work and recover the extra cost so involved from the eligible bidder plus **15%** service charges of the cost of such rectification, from the eligible bidder and/ or terminate the contract for balance work/ supplies with enforcement of penalty **as stated above**.
- b) Defective materials/workmanship will not be accepted under any conditions and shall be rejected outright without compensation. The eligible bidder shall be liable for any loss/damage sustained by CREDA due to defective work **with enforcement of penalty as stated above**.

10. EXTENSION OF THE TIME -

If the completion of work is delayed due to any reason beyond the control of the eligible bidder, the eligible bidder shall without delay give notice to the CREDA in writing of his claim for an extension of time. CREDA on receipt of such notice may or may not agree to extend the contract/delivery/completion date of the Solar System as may be reasonable but without prejudice to other terms and conditions of the contract.

11. MAKES OF EQUIPMENTS TO BE USED IN THE WORK -

- (I) The Solar Modules, Inverters, Structure & Other BOS shall be made in India.
- (II) The eligible bidder has to ensure that equipments are as per Technical Requirements of guidelines of MNRE/CREDA as complied with. The material/works for which MNRE/BIS or ISI specification is not available, engineer-in-charge of the works will examine and approve the material/works, preferably of all makes on which CREDA has report of satisfactory performance. Test certificates for all major equipments should be submitted to the engineer-in-charge of the works before installation of the same.
- (III) Bidder should submit Warrantee Agreement of **at least 5 year** for major components i.e, SPV Modules, Invertors and Structures with manufacturer or dealer certified by the manufacturer before installation of system.

12. WARRANTEE PERIOD AND POST INSTALLATION SERVICES -

- A. The work done/material supplied by the eligible bidder should be warranted for satisfactory operation and against any defect in material and workmanship including Items and other balance of equipment's, for a period of **5(five) years**, from the date of Commissioning of Solar Power Plant including other works as per scope of work.
- B. Warrantee on SPV Modules shall be for 10 (ten) years from the date of commissioning of the SPV System must be warranted for their output peak watt capacity, which should not be less than 90% at the end of 10 years and not less than 80% at the end of 25 years.
- C. The above warrantee certificates shall be furnished to the CREDA for approval. Any defect noticed during this period should be rectified by the supplier free of cost upon written notice from CREDA provided such defects may be due to bad workmanship or bad materials used.
- D. The warrantee period shall be extended by the period during which the items/work remains non-operative due to reasons within control of the eligible bidder.
- E. This warrantee must be an unconditional onsite warrantee and the eligible bidder will have to replace the defective material within **7 days** positively from the date of information given to him.
- F. Care should necessarily be taken to make the SPV Power Plants operational, once the reporting of the fault/non-operational status is done, within a week. If system not found operational even after reporting within **7 days**, the rectification/replacement (keeping the same configuration in consideration) will be done by CREDA at the risk and cost of system integrator, after rectification/replacement the warranty clause will remain compliable as per

tender conditions. No claim in this regard will be entertained.

- G. Eligible Bidder shall have to keep sufficient quantity of spares and man power to ensure proper service network for taking care of smooth functioning of SPV Power Plant installed by them. Bidder shall have to give a contact number to beneficiary to register complaints.

13. **TERMS OF PAYMENT -**

The following terms of payment shall apply for the Bid -

- 97% of the eligible payment as per the work order (excluding the cost of Comprehensive Maintenance) after satisfactory supply, installation, commissioning & after satisfactory synchronization & generation report of minimum one month from the date of synchronization & performance evaluation of the system at site with proper handing over and fulfilling following conditions
 - i) Grid Connectivity Approval letter from the Concern Divisional Office of CSPDCL.
 - ii) Copy of Minutes of Metering (MOM) duly signed by authorized officers of CREDA, CSPDCL and Beneficiary organization at the time of Grid synchronization.
 - iii) Installation of water pipe line for cleaning of Solar Modules as per approval of CREDA.
 - iv) Generation report of minimum one month from the date of synchronization verified by concern CREDA's Regional Office.
- 3% of the eligible payment (without GST) shall be retained by CREDA as performance security for a period of 60 months from the date of commissioning.

The following terms of payment shall be applicable for release of payment of Comprehensive Maintenance: -

1. Date of Synchronization of installed power plant shall be considered as date of Commissioning of plant.
2. Report of Comprehensive maintenance has to be submitted as per attached scope of work every month through concern District & Regional office to SPV Grid Connected Cell of HO, CREDA. Payment would be done after each quarter (Every three months). The five year rate quoted by the successful bidder would be divided by 20 so as to get the rate at which quarterly payment has to be made.
3. Rest of the terms & conditions of the bid would be applicable.

14. **PENALTY FOR DELAY IN COMPLETION OF CONTRACT -**

If the eligible SI fails to complete the assigned work within scheduled time specified in the work order or any extension granted there to, CREDA will recover from the bidder as penalty a sum of **One per cent (1%)** of the Work Order Cost including GST/Taxes for each calendar month of delay or Part thereof. For this purpose, the date of taking over shall be reckoned as the date of completion. Total penalty shall not exceed **5% (Five Per cent)** of the ordered value.

However, imposition of such penalty shall be discretion of CREDA. This penalty may be decrease, increase or waived off due to various justified reasons on ground with recommendations of field staff on record. Period declared as lockdown or local quarantine /containment zones due to Covid-19 pandemic shall be waived off for the purpose of penalty.

Review of the progress of supply/work allocated to bidders shall be done time to time by CREDA. If the progress of supply/work is found unsatisfactory, the allocation of entire remaining works/supply can be re-allocated to other bidder as per discretion of CREDA.

15. SECURITY DEPOSIT (SD) -

- A. The EMD shall be retained as SD for the period of the validity of TENDER. No interest shall be payable on the Security Deposit.
- B. Balance 3% of the eligible payment (Without GST) shall be retained by CREDA as Performance Security for a period of **60 months** from the date of Commissioning.

16. INSURANCE -

The eligible bidder shall arrange insurance coverage for the materials and SPV System at his/beneficiary's custody for the work under execution and successful commissioning and subsequent handover to the beneficiary. The eligible bidder shall take up insurance or such other measures for the manpower so as to cover the claim for damage arising under workmen's compensation Act and other applicable State/Central laws. CREDA shall not bear any responsibility on this account.

17. PENALTY DUE FROM THE ELIGIBLE SI -

All costs of damages and delays for which the eligible bidder is liable to CREDA will be deducted from any money due to the eligible bidder including the security deposit of any project under CREDA.

18. RESPONSIBILITY OF SUCCESSFUL BIDDER'S -

Notwithstanding anything mentioned in the specifications of subsequent approval or acceptance of the System by CREDA, if any, the ultimate responsibility for satisfactory performance of the entrusted work shall rest with the Successful bidders. If in any case the eligible bidder does not complete the work as per the work orders issued to them then CREDA may take over the task & complete the project at the risk and cost of eligible bidder.

19. RESPONSIBILITY TO RECTIFY THE LOSS AND DAMAGE -

If any loss or damage occurs to the work or any part thereof or materials/system/equipment's for incorporation therein the period for which the eligible bidder is responsible for the cause thereof or from any cause whatsoever, the eligible SI shall at his own cost rectify/replace such loss or damage, so that the permanent work confirms in every respect with the provision of the contract to the satisfaction of the Engineer. The eligible SI shall also be liable for any loss or damage to the work/equipment's occasioned by him in course of any operation carried out to him during performing the contract.

20. RESPONSIBILITY TOWARDS THE WORKMAN OR OUTSIDERS -

- A. The eligible bidder shall have to take insurance coverage from any authorized Insurance Company against Workmen compensation due under Workmen Compensation Act and submit copy of the insurance document before issuance of Work Order.
- B. The eligible bidder shall ensure all safety measures during execution and repairs work. CREDA, will, in no case be responsible for any accident fatal or non-fatal, caused to any workman or outsider in course of transport or execution or repairs of work.
- C. All the expenditure including treatment or compensation will be entirely borne by the eligible bidders. The eligible bidder shall also be responsible for any claims of the workers including, labour payments, PF, Gratuity, ESI & other legal obligations.
- D. CREDA shall have all rights to deduct such claims of payments from bidder in case of complaints of such violations.

21. NON-ASSIGNMENTS -

The eligible bidder shall not assign or transfer the sanction orders issued as per this contract or any part thereof without the prior approval of CREDA. If eligible bidder transfer/assigned/sublet full or any part of work allocated to him without prior permission from CREDA in writing to any third party shall be liable to debar/black listed from any Tender/Activity of CREDA till further orders.

22. CERTIFICATES NOT TO AFFECT RIGHTS OF CREDA -

The issuance of any certificate by CREDA or any extension of time granted by CREDA shall not prejudice the rights of CREDA in terms of the contract nor shall they relieve the eligible bidder of his obligations for due performance of the contract.

23. SETTLEMENT OF DISPUTES THROUGH ARBITRATION -

- A. Except as otherwise specifically provided in the contract, all disputes concerning questions of fact arising under the contract shall be decided by the Chief Executive Officer (CEO), CREDA provided a written appeal by the eligible bidder is made to CREDA. The decision of the CEO, CREDA shall be final and binding to the all concerns.
- B. Any dispute or difference including those considered as such by only of the parties arising out of or in connection with the contract shall be to the extent possible be settled amicably between the parties. If amicable settlement cannot be reached then all disputed issues shall be settled by arbitration.

24. LAWS GOVERNING CONTRACT –

The contract shall be constituted according to and subject to the Laws of India and jurisdiction of the High Court of Bilaspur, Chhattisgarh.

25. LANGUAGE AND MEASURES -

All documents pertaining to the Contract including specifications, schedules, notice correspondences, operation and maintenance instructions, drawings or any other writings shall be written in English / Hindi language. The metric system of measurement shall be used in this contract.

26. CORRESPONDENCE -

- A. Any notice to the eligible bidder under the terms of the contract shall be served by registered mail to the registered office of the eligible bidder or by hand to the authorized local representative of the eligible bidder and copy by post to the eligible bidder's principal place of business.
- B. Any notice to CREDA shall be served to the Chief Engineer (RE-V), CREDA Raipur in the same manner.

27. SECRECY -

The eligible bidder shall treat the details of the specifications and other documents as private and confidential and they shall not be reproduced without written authorization from CREDA.

28. AGREEMENT -

The successful eligible SI shall have to enter into an agreement with the CREDA in the approved contract agreement form within **10 days** of the receipt of call from CREDA.

29. DECLARATION OF CONFLICT OF INTEREST –

- A. The bidder shall not be permitted to Bid for the work if the section of HO CREDA (responsible for implementation of work) in which his near relative is posted. Furthermore, the successful bidder shall not be given work in the district in which his near relative is posted. The bidder shall also intimate the names of his near relatives working in the CREDA. Bidder shall also intimate the name of persons who are working with him in any capacity and who are near relatives to any employee in CREDA. Any breach of this condition by SI would render himself liable to be blacklisted for three years and removed from approved list of SI.

Note: - By the term near relatives are meant Wife, Husband, Parents and son, Brother, Sister, Brother-in-law, Father-in-law, and Mother-in-law etc.

- B. Bidder must produce an affidavit (Annexure-III) stating the names of retired/removed employee of CREDA (if any) in his employment who retired /removed within last two years, if in case there is no such person in his employment, his affidavit should clearly state this fact. This affidavit is mandatory, if it is not produced along with the bid, the bid shall be rejected.

30. BID EVALUATION CRITERIA -

- A. Offers of only those parties, who are found qualified based on Eligibility Criteria and Techno-commercial Bid, will be taken into further consideration and financial bid of only those parties who are qualifying the criteria of Techno-commercial Bid will be opened.
- B. Other things being equal, the lowest rates shall normally be preferred, but CREDA shall have rights and liberty to amend/lower the rates.
- C. **Conditional Bids shall not be accepted.**
- D. **Bidders shall ensure that they are applying the appropriate GST rates while quoting the rates in price bid. Bids quoted with faulty GST rates shall be rejected.**
- E. Work shall be awarded only to L1 eligible bidder including rate of maintenance for five years.
- F. In case if there are more than one bidder who have quoted lowest price then the eligible bidder would be evaluated on the basis of following:
 - (i) Bid who had installed more Grid Connected Solar Power Plants in past than the minimum eligibility conditions of the bid.
 - (ii) If both the bidders are eligible with regard to point No (i) above then the bidder who has installed more numbers of higher capacities of Grid connected SPVPP would be preferred.
 - (iii) Decision of CREDA would be final and binding to all bidders in selection of eligible bidder based on above evaluation criteria.

31. EVALUTION OF PRICE BID -

Price bid shall be evaluated on the basis of Quoted rates. Lowest rates of each category of Items/works shall be considered however CREDA shall have discretionary power to amend/lower the rates.

32. BID REJECTION –

If financial bid of a bidder has been opened on the basis of technical bid of a bidder which has been determined to be substantially responsive to the bidding document and in later stage it is found that bidder does not meet the eligibility criteria or the technical bid is found substantially non-responsive, CREDA reserves rights to reject such bid of a bidder any time.

We (on behalf of Eligible SI/Bidder) have read all the above stated details & accept to comply with it in total

(Name, Signature & Seal of the
SI/Bidder)

SECTION - 3

SCOPE OF WORK

The scope of work in brief will be as follows-

1. Survey of site, designing, supply, installation & commissioning of SPV Power Plant systems as per site specific design and specifications approved by CREDA, on turnkey basis. Bidder shall have to take approval of the engineering documents, Bill of Materials and samples from CREDA prior to commencement of the work. Five years unconditional onsite warrantee for manufacturing defects shall be required for each of the system after successful commissioning and proper handing over.
2. The scope of work shall also includes the followings:
 - a) Survey of Sites, Submission of site clearance certificate where the SPV Power Plants are to be installed. A layout plan of the site should also be submitted clearly indicating the identified location for installation of SPV Modules, Structures and other components are proposed to be installed. Work order shall be issued only after receipt of satisfactory reports regarding suitability of system installation. Bidder shall furnish all necessary information to beneficiary for SPV Power Plant Warrantee, Do & Don'ts etc. So as to avoid further misunderstandings and disputes. Brief details of site specific works are as below :-
 - b) **Design, supply, installation & commissioning of SPV Power Plant (SPVPP) of capacity at following sites as per requirement of site:-**
 - i. **Sihawa & Mahamaya Bhawan Building in Pt. Sunder Lal Sharma Open University, Birkona, Bilaspur, Chhattisgarh.200KWP (Contact person for site Inspections Mr. Alok Tiwari (A.E) –8889031113).**
 - ii. **Old Building Building District & Session Court, Raigarh, Chhattisgarh. 30KWP (Contact person for site Inspections Mr. Ranjit Kumar Yadav (D.I.) –9977017491).**
 - iii. **New Building Building District & Session Court, Raigarh, Chhattisgarh. 20 KWP (Contact person for site Inspections Mr. Ranjit Kumar Yadav (D.I.) –9977017491).**
 - c) Detailed planning of time bound smooth execution of project.
 - d) Design, supply, installation & commissioning of SPV Power Plant of required capacities as per design and specifications approved by CREDA, on turnkey basis.
 - e) Get technical and safety clearances of proposed Grid Connected Roof Top SPVPP from the concerned CSPDCL office.
 - f) Co ordinate with beneficiary to get connectivity approval from CSPDCL and to synchronize the system with Grid in presence of CSPDCL and Concerned Officials.
 - g) Providing User Manuals and Warrantee Cards to beneficiary / CREDA.
 - h) Bidder shall have to submit JCCs within 15 days of Installation and Commissioning of SPV Power Plant in District Office of CREDA.
 - i) Unconditional onsite warrantee for manufacturing defects for Five years faultless operation, assure inventory for maintenance.
 - j) Providing Prompt Service Facilities to customers/ beneficiaries.
 - k) Risk liability of all personnel associated with implementation and realization of the project.
 - l) Training of at least two persons nominated by user, on the various aspects of design and maintenance of the offered system after commissioning of the system.
 - m) The eligible bidder shall maintain sufficient inventory of the spares to ensure that the system can be made functional within 7 days from the communication of breakdown of the system during currency of the warrantee period.
 - n) The bidder shall run the system on trial basis and shall closely monitor the performance of the system before handing over the system, so that the assured annual power generation can be estimated for monitoring of the performance of the system. CREDA shall examine the data of generation and ascertain if the generation is adequate with reference to the capacity of the SPV Systems.
 - o) Performance Guarantee Test: Successful performance guarantee test to demonstrate the rated capacity of SPV Power Plant as per CREDA's norms shall have to be conducted by bidder in presence of representatives of CREDA.

SECTION - 4

TECHNICAL SPECIFICATIONS

TECHNICAL SPECIFICATIONS

The proposed projects shall be commissioned as per following technical specifications.

DEFINITION :-

A Grid Tied Solar Rooftop Photovoltaic (SPV) power plant consists of SPV array, Module Mounting Structure, Power Conditioning Unit (PCU) consisting of Maximum Power Point Tracker (MPPT), Inverter, and Controls & Protections, interconnect cables, Junction boxes, Distribution boxes and switches. PV Array is mounted on a suitable structure. Grid tied SPV system should be designed with necessary features to supplement the grid power during day time. Components and parts used in the SPV power plants including the PV modules, metallic structures, cables, junction box, switches, PCUs etc., should conform to the BIS or IEC or international specifications, wherever such specifications are available and applicable. Solar PV system shall consist of following equipments/components.

- Solar PV modules consisting of required number of Crystalline PV cells.
- Grid interactive Power Conditioning Unit with Remote Monitoring System
- Mounting structures
- Junction Boxes.
- Earthing and lightening protections.
- IR/UV protected PVC Cables, pipes and accessories.

i. SOLAR PHOTOVOLTAIC MODULES :-

- i) The PV modules used should be made in India.
- ii) The PV modules used must qualify to the latest edition of IEC PV module qualification test or equivalent BIS standards Crystalline Silicon Solar Cell Modules IEC 61215/IS14286. In addition, the modules must conform to IEC 61730 Part-1 - requirements for construction & Part 2 – requirements for testing, for safety qualification or equivalent IS.
- iii) For the PV modules to be used in a highly corrosive atmosphere throughout their lifetime, they must qualify to IEC 61701.
- iv) The total solar PV array capacity should not be less than allocated capacity (kWp) and should comprise of solar crystalline modules of minimum 300 Wp and above wattage. Module capacity less than minimum 300 watts shall not be accepted.
- v) Protective devices against surges at the PV module shall be provided. Low voltage drop bypass diodes shall be provided.
- vi) PV modules must be tested and approved by one of the IEC authorized test centres.
- vii) The module frame shall be made of corrosion resistant materials, preferably having anodized aluminium.
- viii) The Bidder shall carefully design & accommodate requisite numbers of the modules to achieve the rated power in his Bidder. CREDA shall allow only minor changes at the time of execution.
- ix) Other general requirement for the PV modules and subsystems shall be the Following:
 - The rated output power of any supplied module shall have tolerance within +/-3%.
 - The peak-power point voltage and the peak-power point current of any supplied module and/or any module string (series connected modules) shall not vary by more than 2 (two) per cent from the respective arithmetic means for all modules and/or for all module strings, as the case may be.
 - The module shall be provided with a junction box with either provision of external screw terminal connection or sealed type and with arrangement for provision of by-pass diode. The box shall have hinged, weather proof lid with captive screws and cable gland entry points or may be of sealed type and IP-65 rated.
 - I-V curves at STC should be provided by Bidder.

ii. SOLAR PV MODULES :-

All the modules should contain the following clear and indelible marking laminated inside the glass as per IS/ IEC 61730-1, clause 11.

- a) Name, monogram or symbol of manufacturer;
- b) Model number
- c) Unique serial number
- d) Nominal wattage $\pm 2\%$
- e) Year and country of origin
- f) Brand name if applicable

Other details as per IS/IEC 61730-1 clause 11 should be provided at appropriate place. The actual Power Output P_{max} shall be mentioned on the label pasted on the back side of PV Module. In case of thin film modules information need not be provided laminated inside the glass, however, it should be provided as per IS/IEC 61730-1 clause 11 at an appropriate place with clear and indelible marking.

In addition to the above, the following information should also be provided

- Polarity of terminals or leads (colour coding is permissible) on junction Box housing near cable entry or cable and connector.
- The Maximum system voltage for which the module is suitable to be provided on the back sheet of the module.

iii. WARRANTIES :-

i) Material Warranty:

- Material Warranty is defined as: The project developer should warrant the Solar Module(s) to be free from the defects and/or failures specified below for a period not less than five (05) years from the date of sale to the original customer ("Customer")
- Defects and/or failures due to manufacturing
- Defects and/or failures due to quality of materials
- Non conformity to specifications due to faulty manufacturing and/or inspection processes. If the solar Module(s) fails to conform to this warranty, the project developer will repair or replace the solar module(s), at the Owners sole option.

ii) Performance Warranty:

The predicted electrical degradation of power generated not exceeding 20% of the minimum rated power over the 25 year period and not more than 10% after ten years period of the full rated original output.

iv. ARRAY STRUCTURE :-

- i) Hot dip galvanized MS mounting structures may be used for mounting the modules / panels / arrays. Minimum thickness of galvanization should be at least 120 microns. Each structure should have angle of inclination as per the site conditions to take maximum insolation. However to accommodate more capacity the angle inclination may be reduced until the plant meets the specified performance ratio requirements.
- ii) The Mounting structure shall be so designed to withstand the speed for the wind zone of the location where a PV system is proposed to be installed (wind speed of 150 km/ hour). It may be ensured that the design has been certified by a recognized Lab/ Institution in this regard and submit wind loading calculation sheet to CREDA. Suitable fastening arrangement such as grouting and calming should be provided to secure the installation against the specific wind speed.
- iii) The mounting structure steel shall be as per latest IS 2062: 1992 and galvanization of the mounting structure shall be in compliance of latest IS 4759.
- iv) Structural material shall be corrosion resistant and electrolytically compatible with the materials used in the module frame, its fasteners, nuts and bolts. Aluminium structures also can be used which can withstand the wind speed of respective wind zone. Necessary protection towards rusting need to be provided either by coating or anodization.
- v) Aluminium frames should be avoided for installations in coastal areas.

- vi) The fasteners used should be made up of stainless steel. The structures shall be designed to allow easy replacement of any module. The array structure shall be so designed that it will occupy minimum space without sacrificing the output from the SPV panels.
- vii) Regarding civil structures the Bidder need to take care of the load bearing capacity of the roof and need arrange suitable structures based on the quality of roof.
- viii) The total load of the structure (when installed with PV modules) on the terrace should be less than 60 kg/m².
- ix) The minimum clearance of the structure from the roof level should be 300 mm.

v. JUNCTION BOXES (JBs) :-

- i) The junction boxes are to be provided in the PV array for termination of connecting cables. The J. Boxes (JBs) shall be made of GRP / FRP / Powder Coated Aluminium /cast aluminium alloy with full dust, water & vermin proof arrangement. All wires / cables must be terminated through cable lugs. The JB's shall be such that input & output termination can be made through suitable cable glands.
- ii) Copper bus bars / terminal blocks housed in the junction box with suitable termination threads conforming to IP65 standard and IEC 62208 Hinged door with EPDM rubber gasket to prevent water entry. Single / double compression cable glands. Provision of earthings. It should be placed at 5 feet height or above for ease of accessibility.
- iii) Each Junction Box shall have High quality Suitable capacity Metal Oxide Varistors (MOVs) / SPDs, suitable Reverse Blocking Diodes. The Junction Boxes shall have suitable arrangement monitoring and disconnection for each of the groups.
- iv) Suitable markings shall be provided on the bus bar for easy identification and the cable ferrules must be fitted at the cable termination points for identification.
- v) All fuses shall have DIN rail mountable fuse holders and shall be housed in thermoplastic IP 65 enclosures with transparent covers.

vi. DC DISTRIBUTION BOARD :-

- i) DC Distribution panel to receive the DC output from the array field.
- ii) DC DPBs shall have sheet from enclosure of dust & vermin proof conform to IP 65 protection. The bus bars are made of copper of desired size. Suitable capacity MCBs/MCCB shall be provided for controlling the DC power output to the PCU along with necessary surge arrestors.

vii. AC DISTRIBUTION PANEL BOARD :-

- i) AC Distribution Panel Board (DPB) shall control the AC power from PCU/ inverter, and should have necessary surge arrestors. Interconnection from ACDB to mains at LT Bus bar while in grid tied mode.
- ii) All switches and the circuit breakers, connectors should conform to IEC 60947, part I, II and III/ IS 60947 part I, II and III.
- iii) The changeover switches, cabling work should be undertaken by the Bidder as part of the project.
- iv) All the Panel's shall be metal clad, totally enclosed, rigid, floor mounted, air - insulated, cubical type suitable for operation on three phase / single phase, 415 or 230 volts, 50 Hz
- v) The panels shall be designed for minimum expected ambient temperature of 45 degree Celsius, 80 percent humidity and dusty weather.
- vi) All indoor panels will have protection of IP54 or better. All outdoor panels will have protection of IP65 or better.
- vii) Should conform to Indian Electricity Act and rules (till last amendment).
- viii) All the 415 AC or 230 volts devices / equipment like bus support insulators, circuit breakers, SPDs, VTs etc., mounted inside the switchgear shall be suitable for continuous operation and satisfactory performance under the following supply conditions

Variation in supply voltage	+/- 10 %
Variation in supply frequency	+/- 3 Hz

PCU / ARRAY SIZE RATIO :-

- ix) The combined wattage of all inverters should not be less than rated capacity of power plant under STC.
- x) Maximum power point tracker shall be integrated in the PCU/inverter to maximize energy drawn from the array.

viii. PCU / INVERTER :-

- i) As SPV array produce direct current electricity, it is necessary to convert this direct current into alternating current and adjust the voltage levels to match the grid voltage. Conversion shall be achieved using an electronic Inverter and the associated control and protection devices. All these components of the system are termed the “Power Conditioning Unit (PCU)”. In addition, the PCU shall also house MPPT (Maximum Power Point Tracker), an interface between Solar PV array & the Inverter, to the power conditioning unit/inverter should also be DG set interactive. If necessary. Inverter output should be compatible with the grid frequency. Typical technical features of the inverter shall be as follows:

ii)

Switching devices	IGBT/MOSFET
Control	Microprocessor /DSP
Nominal AC output voltage and frequency	415V, 3 Phase, 50 Hz (In case single phase inverters are offered, suitable arrangement for balancing the phases must be made.)
Output frequency	50 Hz
Grid Frequency Synchronization range	+ 3 Hz or more
Ambient temperature considered	-20° C to 50° C
Humidity	95 % Non-condensing
Protection of Enclosure	IP-20(Minimum) for indoor. IP-65(Minimum) for outdoor.
Grid Frequency Tolerance range	+ 3 or more
Grid Voltage tolerance	-0.20.15
No-load losses	Less than 1% of rated power
Inverter efficiency(minimum)	>93% (In case of 10 kW or above with in- built galvanic isolation) >97% (In case of 10 KW or above without in-built galvanic isolation)
Inverter efficiency (minimum)	> 90% (In case of less than 10 kW)
THD	< 3%
PF	> 0.9

- a. Three phase PCU/ inverter shall be used with each power plant system (10kW and/or above) but in case of less than 10kW single phase inverter can be used.
- b. PCU / inverter shall be capable of complete automatic operation including wake-up, synchronization & shutdown.
- c. The output of power factor of PCU inverter is suitable for all voltage ranges or sink of reactive power, inverter should have internal protection arrangement against any sustainable fault in feeder line and against the lightning on feeder.
- d. Built-in meter and data logger to monitor plant performance through external computer shall

- be provided.
- e. **Anti-islanding** (Protection against Islanding of grid): The PCU shall have anti islanding protection in conformity to IEEE 1547/UL 1741/ IEC 62116 or equivalent BIS standard.
 - f. Successful bidders shall be responsible for galvanic isolation of solar roof top power plant (>100kW) with electrical grid or LT panel.
 - g. In PCU/Inverter, there shall be a direct current isolation provided at the output by means of a suitable isolating transformer. If Isolation Transformer is not incorporated with PCU/Inverter, there shall be a separate Isolation Transformer of suitable rating provided at the output side of PCU/PCU units for capacity more than 100 kW.
 - h. The PCU/ inverter generated harmonics, flicker, DC injection limits, Voltage Range, Frequency Range and Anti-Islanding measures at the point of connection to the utility services should follow the latest CEA (Technical Standards for Connectivity Distribution Generation Resources) Guidelines.
 - i. The power conditioning units / inverters should comply with applicable IEC/ equivalent BIS standard for efficiency measurements and environmental tests as per standard codes IEC 61683/IS 61683 and IEC 60068-2 (1,2,14,30)/ Equivalent BIS Std.
 - j. The MPPT units environmental testing should qualify IEC 60068-2 (1, 2, 14, 30)/ Equivalent BIS std. The junction boxes/ enclosures should be IP 65 (for outdoor)/ IP 54 (indoor) and as per IEC 529 specifications.
 - k. The PCU / inverters should be tested from the MNRE approved test centers / NABL / BIS / IEC accredited testing- calibration laboratories. In case of imported power conditioning units, these should be approved by international test houses.

ix. INTEGRATION OF PV POWER WITH GRID :-

The output power from SPV would be fed to the inverters which converts DC produced by SPV array to AC and feeds it into the main electricity grid after synchronization. In case of grid failure, or low or high voltage, solar PV system shall be out of synchronization and shall be disconnected from the grid. Once the DG set comes into service, PV system shall again be synchronized with DG supply and load requirement would be met to the extent of availability of power. 4 pole isolation of inverter output with respect to the grid/ DG power connection need to be provided.

x. DATA ACQUISITION SYSTEM / PLANT MONITORING :-

- i) Data Acquisition System shall be provided for each of the solar PV plant above 10 kWp capacity.
- ii) Data Logging Provision for plant control and monitoring, time and date stamped system data logs for analysis with the high quality, suitable PC. Metering and Instrumentation for display of systems parameters and status indication to be provided.
- iii) Temperature: Temperature probes for recording the Solar panel temperature and/or ambient temperature to be provided complete with readouts integrated with the data logging system.
- iv) The following parameters are accessible via the operating interface display in real time separately for solar power plant:
 - A. AC Voltage.
 - B. AC Output current.
 - C. Output Power
 - D. Power factor.
 - E. DC Input Voltage.
 - F. DC Input Current.
 - G. Time Active.
 - H. Time disabled.
 - I. Time Idle.
 - J. Power produced
 - K. Protective function limits (Viz-AC Over voltage, AC Under voltage, over frequency, under frequency ground fault, PV starting voltage, PV stopping voltage.
- v) All major parameters available on the digital bus and logging facility for energy auditing through

the internal microprocessor and read on the digital front panel at any time) and logging facility (the current values, previous values for up to a month and the average values) should be made available for energy auditing through the internal microprocessor and should be read on the digital front panel.

- vi) PV array energy production: Digital Energy Meters to log the actual value of AC/ DC voltage, Current & Energy generated by the PV system provided. Energy meter along with CT/PT should be of 0.5 accuracy class.
- vii) Computerized DC String/Array monitoring and AC output monitoring shall be provided as part of the inverter and/or string/array combiner box or separately.
- viii) String and array DC Voltage, Current and Power, Inverter AC output voltage and current (All 3 phases and lines), AC power (Active, Reactive and Apparent), Power Factor and AC energy (All 3 phases and cumulative) and frequency shall be monitored.
- ix) Computerized AC energy monitoring shall be in addition to the digital AC energy meter.
- x) The data shall be recorded in a common work sheet chronologically date wise. The data file shall be MS Excel compatible. The data shall be represented in both tabular and graphical form.
- xi) All instantaneous data shall be shown on the computer screen.
- xii) Software shall be provided for USB download and analysis of DC and AC parametric data for individual plant.
- xiii) Provision for instantaneous Internet monitoring and download of historical data shall be also incorporated.
- xiv) Remote Server and Software for centralized Internet monitoring system shall be also provided for download and analysis of cumulative data of all the plants and the data of the solar radiation and temperature monitoring system.
- xv) Ambient/Solar PV module back surface temperature shall be also monitored on continuous basis.
- xvi) Simultaneous monitoring of DC and AC electrical voltage, current, power, energy and other data of the plant for correlation with solar and environment data shall be provided.
- xvii) Remote Monitoring and data acquisition through Remote Monitoring System software at the CREDA location with latest software/hardware configuration and service connectivity for online / real time data monitoring / control complete to be supplied and operation and maintenance / control to be ensured by the Bidder.
- xviii) The Bidder shall be obligated to push real-time plant monitoring data on a specified intervals (say 15 minute) through open protocol at receiver location (cloud server) in XML/JSON format, preferably. Suitable provision in this regard will be intimated to the Bidder.

xi. TRANSFORMER “IF REQUIRED” & METERING :-

- a) Dry/oil type relevant kVA, 11kV/415V, 50 Hz Step up along with all protections, switchgears, Vacuum circuit breakers, cables etc. along with required civil work.
- b) The Bi-directional electronic energy meter (0.5 S class) shall be installed for the measurement of import/Export of energy.
- c) The Bidder must take approval/NOC from the Concerned DISCOM for the connectivity, technical feasibility, and synchronization of SPV plant with distribution network before commissioning of SPV plant.
- d) Reverse power relay shall be provided by Bidder (if necessary), as per the local DISCOM requirement.

xii. POWER CONSUMPTION:

Regarding the generated power consumption, priority need to give for internal consumption first and thereafter any excess power can be exported to grid. Decisions of appropriate authority like DISCOM, state regulator may be followed.

xiii. PROTECTIONS :-

The system should be provided with all necessary protections like earthing, Lightning, and grid islanding as follows:

A. LIGHTNING PROTECTION :-

The SPV power plants shall be provided with lightning & overvoltage protection. The main aim in this protection shall be to reduce the over voltage to a tolerable value before it reaches the PV or other sub system components. The source of over voltage can be lightning, atmosphere disturbances etc. The entire space occupying the SPV array shall be suitably protected against Lightning by deploying required number of Lightning Arrestors. Lightning protection should be provided as per IEC 62305 standards. The protection against induced high-voltages shall be provided by the use of metal oxide varistors (MOVs) and suitable earthing such that induced transients find an alternate route to earth.

B. SURGE PROTECTION :-

Internal surge protection shall consist of three MOV type surge-arrestors connected from +ve and -ve terminals to earth (via Y arrangement).

C. EARTHING PROTECTION :-

- i) Each array structure of the PV yard should be grounded/ earthed properly as per IS:3043-1987. In addition the lightning arrester/masts should also be earthed inside the array field. Earth Resistance shall be tested in presence of the representative of Department/CREDA as and when required after earthing by calibrated earth tester. PCU, ACDB and DCDB should also be earthed properly.
- ii) Earth resistance shall not be more than 5 ohms. It shall be ensured that all the earthing points are bonded together to make them at the same potential.

D. GRID ISLANDING :-

- i) In the event of a power failure on the electric grid, it is required that any independent power-producing inverters attached to the grid turn off in a short period of time. This prevents the DC-to-AC inverters from continuing to feed power into small sections of the grid, known as "Islands." Powered Islands present a risk to workers who may expect the area to be unpowered, and they may also damage grid-tied equipment. The Rooftop PV system shall be equipped with islanding protection. In addition to disconnection from the grid (due to islanding protection) disconnection due to under and over voltage conditions shall also be provided.
- ii) A manual disconnect 4-pole isolation switch beside automatic disconnection to grid would have to be provided at utility end to isolate the grid connection by the utility personnel to carry out any maintenance. This switch shall be locked by the utility personnel.

xiv. CABLES :-

Cables of appropriate size to be used in the system shall have the following characteristics:

- a) Shall meet IEC 60227/IS 694, IEC 60502/IS1554 standards
- b) Temp. Range: -10°C to +80°C.
- c) Voltage rating 660/1000V
- d) Excellent resistance to heat, cold, water, oil, abrasion, UV radiation
- e) Flexible
- f) Sizes of cables between array interconnections, array to junction boxes, junction boxes to Inverter etc. shall be so selected to keep the voltage drop (power loss) of the entire solar system to the minimum (2%)
- g) For the DC cabling, XLPE or, XLPO insulated and sheathed, UV- stabilized single core multi-stranded flexible copper cables shall be used; Multi-core cables shall not be used.
- h) For the AC cabling, PVC or, XLPE insulated and PVC sheathed single or, multi-core multi-stranded flexible copper cables shall be used; Outdoor AC cables shall have a UV-stabilized outer sheath.
- i) The cables (as per IS) should be insulated with a special grade PVC compound formulated for

- outdoor use. Outer sheath of cables shall be electron beam cross-linked XLPO type and black in colour.
- j) The DC cables from the SPV module array shall run through a UV- stabilized PVC conduit pipe of adequate diameter with a minimum wall thickness of 1.5mm.
 - k) Cables and wires used for the interconnection of solar PV modules shall be provided with solar PV connectors (MC4) and couplers.
 - l) All cables and conduit pipes shall be clamped to the rooftop, walls and ceilings with thermo-plastic clamps at intervals not exceeding 50 cm; the minimum DC cable size shall be 4.0 mm² copper; the minimum AC cable size shall be 4.0 mm² copper. In three phase systems, the size of the neutral wire size shall be equal to the size of the phase wires.
 - m) Cable Routing / Marking: All cable/wires are to be routed in a GI cable tray and suitably tagged and marked with proper manner by good quality ferule or by other means so that the cable easily identified. In addition, cable drum no. / Batch no. to be embossed/ printed at every one meter.
 - n) Cable Jacket should also be electron beam cross-linked XLPO, flame retardant, UV resistant and black in colour.
 - o) All cables and connectors for use for installation of solar field must be of solar grade which can withstand harsh environment conditions including High temperatures, UV radiation, rain, humidity, dirt, salt, burial and attack by moss and microbes for 25 years and voltages as per latest IEC standards. DC cables used from solar modules to array junction box shall be solar grade copper (Cu) with XLPO insulation and rated for 1.1kV as per relevant standards only.
 - p) The ratings given are approximate. Bidder to indicate size and length as per system design requirement. All the cables required for the plant shall be provided by the Bidder. Any change in cabling sizes if desired by the Bidder shall be approved after citing appropriate reasons. All cable schedules/ layout drawings shall be approved prior to installation.
 - q) Multi Strand, Annealed high conductivity copper conductor PVC type 'A' pressure extruded insulation or XLPE insulation. Overall PVC/XLPE insulation for UV protection Armoured cable for underground laying. All cable trays including covers to be provided. All cables conform to latest edition of IEC/ equivalent BIS Standards as specified below: BoS item / component Standard Description Standard Number Cables General Test and Measuring Methods, PVC/XLPE insulated cables for working Voltage up to and including 1100 V, UV resistant for outdoor installation IS /IEC 69947.
 - r) The total voltage drop on the cable segments from the solar PV modules to the solar grid inverter shall not exceed 2.0%.
 - s) The total voltage drop on the cable segments from the solar grid inverter to the building distribution board shall not exceed 2.0%.

xv. CONNECTIVITY :-

The maximum capacity for interconnection with the grid at a specific voltage level shall be as specified in the Distribution Code/Supply Code of the State and amended from time to time. Following criteria have been suggested for selection of voltage level in the distribution system for ready reference of the solar suppliers.

Plant Capacity	Connecting voltage
Up to 10 kW	240V-single phase or 415V-three phase at the option of the consumer
Above 10kW and up to 100 kW	415V – three phase
Above 100kW	At HT/EHT (11kV/33kV/66kV) as per level DISCOM rules

xvi. TOOLS & TACKLES AND SPARES :-

- a) After completion of installation & commissioning of the power plant, necessary tools & tackles are to be provided free of cost by the Bidder for maintenance purpose. List of tools and tackles to be supplied by the Bidder for approval of specifications and make from CREDA.
- b) A list of requisite spares in case of PCU/inverter comprising of a set of control logic cards, IGBT driver cards etc. Junction Boxes. Fuses, MOVs / arrestors, MCCBs etc along with spare set of PV modules be indicated, which shall be supplied along with the equipment. A minimum set of spares shall be maintained in the plant itself for the entire period of warranty and Operation & Maintenance which upon its use shall be replenished.

xvii. DANGER BOARDS AND SIGNAGES :-

Danger boards should be provided as and where necessary as per IE Act. /IE rules as amended up to date. Three signage shall be provided one each at battery –cum- control room, solar array area and main entry from administrative block. Text of the signage may be finalized in consultation with CREDA.

xviii. FIRE EXTINGUISHERS :-

The fire fighting system for the proposed power plant for fire protection shall be consisting of:

- a) Portable fire extinguishers in the control room for fire caused by electrical short circuits.
- b) Sand buckets in the control room.
- c) The installation of Fire Extinguishers should confirm to TAC regulations and BIS standards. The fire extinguishers shall be provided in the control room housing PCUs as well as on the Roof or site where the PV arrays have been installed.

xix. DRAWINGS & MANUALS :-

- a) Two sets of Engineering, electrical drawings and Installation and O&M manuals are to be supplied. Bidder shall provide complete technical data sheets for each equipment giving details of the specifications along with make/makes in their Bidder along with basic design of the power plant and power evacuation, synchronization along with protection equipment.
- b) Approved ISI and reputed makes for equipment be used.
- c) For complete electro-mechanical works, Bidder shall supply complete design, details and drawings for approval to CREDA before progressing with the installation work.

xx. PLANNING AND DESIGNING:

The Bidder should carry out Shadow Analysis at the site and accordingly design strings & arrays layout considering optimal usage of space, material and labour. The Bidder should submit the array layout drawings along with Shadow Analysis Report to CREDA for approval.

xxi. DRAWINGS TO BE FURNISHED BY CHANNEL PARTNER AFTER AWARD OF CONTRACT FROM BENEFICIARY:-

- a) The Contractor shall furnish the following drawings Award/Intent and obtain approval.
- b) General arrangement and dimensioned layout.
- c) Schematic drawing showing the requirement of SV panel, Power conditioning Unit(s)/ inverter, Junction Boxes, AC and DC Distribution Boards, meters etc.
- d) Structural drawing along with foundation details for the structure.
- e) Itemized bill of material for complete SPV plant covering all the components and associated accessories.
- f) Layout of solar Power Array.
- g) Shadow analysis of the roof.

xxii. SOLAR PV SYSTEM ON THE ROOFTOP FOR MEETING THE ANNUAL ENERGY REQUIREMENT:-

The Solar PV system on the rooftop of the selected buildings will be installed for meeting upto

90% of the annual energy requirements depending upon the area of rooftop available and the remaining energy requirement of the buildings will be met by drawing power from grid at commercial tariff of DISCOMs.

xxiii. SAFETY MEASURES :-

The Bidder shall take entire responsibility for electrical safety of the installation(s) including connectivity with the grid and follow all the safety rules & regulations applicable as per Electricity Act, 2003 and CEA guidelines etc.

xxiv. DISPLAY BOARD :-

The Bidder has to display a board at the project site (above 10 kWp) mentioning the Following:-

- a) Plant Name, Capacity, Location, Type of Renewable Energy plant (Like solar wind etc.), Date of commissioning, details of tie-up with transmission and distribution companies, Power generation and Export FY wise.
- b) Financial Assistance details from CREDA/MNRE/Any other financial institution apart from loan. This information shall not be limited to project site but also be displayed at site offices/head quarter offices of the successful Bidder.
- c) The size and type of board and display shall be appropriate.

Quality Certification, Standards and Testing for Grid-connected Rooftop Solar PV Systems/Power Plants

Quality certification and standards for grid-connected rooftop solar PV systems are essential for the successful mass-scale implementation of this technology. It is also imperative to put in place an efficient and rigorous monitoring mechanism, adherence to these standards. Hence, all components of grid-connected rooftop solar PV system/ plant must conform to the relevant standards and certifications given below:

Solar PV Modules/Panels	
IEC 61215/ IS14286	Design Qualification and Type Approval for Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
IEC 61701	Salt Mist Corrosion Testing of Photovoltaic (PV) Modules
IEC 61853- Part 1/ IS 16170: Part 1	Photovoltaic (PV) module performance testing and energy rating –: Irradiance and temperature performance measurements, and power rating
IEC 62716	Photovoltaic (PV) Modules – Ammonia (NH ₃) Corrosion Testing (As per the site condition like dairies, toilets)
IEC 61730-1,2	Photovoltaic (PV) Module Safety Qualification – Part 1: Requirements for Construction, Part 2: Requirements for Testing
IEC 62804	Photovoltaic (PV) modules - Test methods for the detection of Potential-induced degradation. IEC TS 62804-1: Part 1: Crystalline silicon (mandatory for applications where the system voltage is > 600 VDC and advisory for installations where the system voltage is < 600 VDC)
IEC 62759-1	Photovoltaic (PV) modules – Transportation testing, Part 1: Transportation and shipping of module package units

Solar PV Inverters	
IEC 62109-1, IEC 62109-2	<p>Safety of power converters for use in photovoltaic power systems –</p> <p>Part 1: General requirements, and Safety of power converters</p>
	<p>for use in photovoltaic power systems</p> <p>Part 2: Particular requirements for inverters. Safety compliance (Protection degree IP 65 for outdoor mounting, IP 54 for indoor mounting)</p>
IEC/IS 61683 (as applicable)	Photovoltaic Systems – Power conditioners: Procedure for Measuring Efficiency (10%, 25%, 50%, 75% & 90-100% Loading Conditions)
BS EN 50530 (as applicable)	<p>Overall efficiency of grid-connected photovoltaic inverters:</p> <p>This European Standard provides a procedure for the measurement of the accuracy of the maximum power point tracking (MPPT) of inverters, which are used in grid- connected photovoltaic systems. In that case the inverter energizes a low voltage grid of stable AC voltage and constant frequency. Both the static and dynamic MPPT efficiency is considered.</p>
IEC 62116/ UL 1741/ IEEE 1547 (as applicable)	Utility-interconnected Photovoltaic Inverters - Test Procedure of Islanding Prevention Measures
IEC 60255-27	Measuring relays and protection equipment – Part 27: Product safety requirements
IEC 60068-2 (1, 2, 14, 27, 30 & 64)	<p>Environmental Testing of PV System – Power Conditioners and Inverters</p> <p>a) IEC 60068-2-1: Environmental testing - Part 2-1: Tests - Test A: Cold</p> <p>b) IEC 60068-2-2: Environmental testing - Part 2-2: Tests - Test B: Dry heat</p> <p>c) IEC 60068-2-14: Environmental testing - Part 2-14: Tests - Test N: Change of temperature</p> <p>d) IEC 60068-2-27: Environmental testing - Part 2-27: Tests - Test Ea and guidance: Shock</p> <p>e) IEC 60068-2-30: Environmental testing - Part 2-30: Tests - Test Db: Damp heat, cyclic (12 h + 12 h cycle)</p> <p>f) IEC 60068-2-64: Environmental testing - Part 2-64: Tests - Test Fh: Vibration, broadband random and guidance</p>
IEC 61000 – 2,3,5 (as applicable)	Electromagnetic Interference (EMI) and Electromagnetic Compatibility (EMC) testing of PV Inverters

Fuses	
IS/IEC 60947 (Part 1, 2 & 3), EN 50521	General safety requirements for connectors, switches, circuit breakers (AC/DC): a) Low-voltage Switchgear and Control-gear, Part 1: General rules b) Low-Voltage Switchgear and Control-gear, Part 2: Circuit Breakers c) Low-voltage switchgear and Control-gear, Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units d) EN 50521: Connectors for photovoltaic systems – Safety requirements and tests
IEC 60269-6	Low-voltage fuses - Part 6: Supplementary requirements for fuse-links for the protection of solar photovoltaic energy systems
Surge Arrestors	
IEC 62305-4	Lightening Protection Standard
IEC 60364-5-53/IS 15086-5 (SPD)	Electrical installations of buildings - Part 5-53: Selection and erection of electrical equipment - Isolation, switching and control
IEC 61643-11:2011	Low-voltage surge protective devices - Part 11: Surge protective devices connected to low-voltage power systems - Requirements and test methods
Cables	
IEC 60227/IS 694, IEC 60502/IS 1554 (Part 1 & 2)/ IEC69947	General test and measuring method for PVC (Polyvinyl chloride) insulated cables (for working voltages up to and including 1100 V, and UV resistant for outdoor installation)
BS EN 50618	Electric cables for photovoltaic systems (BT(DE/NOT)258), mainly for DC Cables

Earthing /Lightning	
IEC 62561 Series (Chemical earthing)	IEC 62561-1 Lightning protection system components (LPSC) - Part 1: Requirements for connection components IEC 62561-2 Lightning protection system components (LPSC) - Part 2: Requirements for conductors and earth electrodes IEC 62561-7 Lightning protection system components (LPSC) - Part 7: Requirements for earthing enhancing compounds
Junction Boxes	
IEC 60529	Junction boxes and solar panel terminal boxes shall be of the thermo-plastic type with IP 65 protection for outdoor use, and IP 54 protection for indoor use
Energy Meter	
IS 16444 or as specified by the DISCOMs	A.C. Static direct connected watt-hour Smart Meter Class 1 and 2 — Specification (with Import & Export/Net energy measurements)
Solar PV Roof Mounting Structure	
IS 2062/IS 4759	Material for the structure mounting

Note- Equivalent standards may be used for different system components of the plants. In case of clarification following person/agencies may be contacted.

- ☐ Ministry of New and Renewable Energy (Govt. of India)
- ☐ National Institute of Solar Energy
- ☐ The Energy & Resources Institute
- ☐ TÜV Rheinland
- ☐ UL

Comprehensive Maintenance Guidelines of Grid Connected PV Plants

TO BE MANDATORILY FOLLOWED BY BIDDER

For the optimal operation of a PV plant, maintenance must be carried out on a regular basis. All the components should be kept clean. It should be ensured that all the components are fastened well at their due place. Maintenance guidelines for various components viz. solar panels, inverter, wiring etc. are discussed below. The Comprehensive Maintenance of Solar Photovoltaic Power Plant would include wear, tear, overhauling, machine breakdown, insurance, and replacement of defective modules, invertors / Power Conditioning Unit (PCU) spares, consumables & other Part for a period of 5 years systems.

The bidder shall be responsible for all the required activities for successful Comprehensive maintenance of the Rooftop Solar PV system for a period of 5 years.

- Comprehensive Maintenance of Solar Power Plant shall be compliant with grid requirements to achieve committed energy generation.
- **Arrangement of qualified and experienced engineer/ technicians till the Comprehensive Maintenance period for projects.**
- Periodic cleaning of solar modules.
- Periodic checks of the Modules, PCUs and BoS shall be carried out as a Part of routine preventive and breakdown maintenance.
- Immediate replacement of defective Modules, Invertors/PCUs and other equipment as and when required.
- Supply of all spares, consumables and fixtures as required. Such stock shall be maintained for all associated equipments and materials as per manufacturer/ supplier's recommendations.
- The entire equipment testing instrument required for Testing, Commissioning and Comprehensive Maintenance for the healthy operation of the Plant shall be maintained by the Bidder. The testing equipments must be calibrated once every 2 years from NABL accredited labs and the certificate of calibration must be kept for reference as required.
- If negligence/ mal-operation on Part of the Bidder's operator results in failure of equipment, such equipment should be repaired/ replaced by the Bidder free of cost.
- Co-ordination with Beneficiaries/DISCOM as per the requirement for Joint Metering Report (JMR). The person in charge present at site from bidder's side shall take a joint meter reading in the presence of rooftop owner on a **monthly basis**. Furnishing generation data (JMR) each month to CREDA positively by 1st week of every month for the previous month. Failure to adhere may result in non-disbursal of subsidy.
- Online Performance Monitoring, controlling, troubleshooting, maintaining of logs & records. A maintenance record register is to be maintained by the operator with effect from Commissioning to record the daily generation on monthly basis, regular maintenance work carried out as well as any preventive and breakdown maintenance along with the date of maintenance, reasons for the breakdown, duration of the breakdown, steps taken to attend the breakdown, etc.
- For any issues related to Comprehensive maintenance, a toll-free number shall be made available to the rooftop owner/ plant owner to **attend** within 72 hours. If not attended within such stipulated time, a complaint may be raised to CREDA, pursuant to which, a penalty of Rs. 10,000 for full month or more shall be imposed for a system capacity above 100 kWp. This will be applicable till 5 years of Comprehensive Maintenance as per the Scope of the bid.
- If any jobs covered in Comprehensive Maintenance Scope as per bid are not carried out by the Bidder during the Comprehensive Maintenance period, the Engineer-In-Charge shall take appropriate action as deemed fit. CREDA reserves the right to make surprise checks/ inspection visits at its own or through authorized representative to verify the Comprehensive Maintenance activities being carried out by the Bidder. Failure to adhere to above guidelines will result in penal action including debarring from Participation in next bid.
- if a system is non operational for more than seven days than warrantee period shall extend for the period in which system is non operational.

METERING AND GRID CONNECTIVITY

Metering and grid connectivity of the roof top solar PV system under this scheme would be the responsibility of the Bidder in accordance with the prevailing guidelines of the concerned DISCOM and / or CEA (if available by the time of implementation). CREDA could facilitate connectivity; however, the entire responsibility lies with bidder only.

PLANT PERFORMANCE EVALUATION

Average CUF of 15% annually should be maintained for a period of 5 years. The bidder should send the monthly plant output details to CREDA for ensuring the CUF in prescribed format along with the reading of import and export measured through the CSPDCL Consumer Energy Meter.

PROGRESS REPORT

The bidder shall submit the progress report monthly to **CREDA** in Prescribed Performa. **If the monthly generation report is not received regularly for more than three months in continuation than the Bidder shall be proposed for black listing for at least two years or for the period as decided by CREDA.** CREDA will have the right to depute it's representatives to ascertain the progress of contract at the premises of works of the bidder.

Submission of Comprehensive Maintenance Report (CMR)

The bidder shall submit the Monthly Comprehensive Maintenance Report mandatorily to CREDA as per the Format enclosed at **Annexure A, every month**. Non submission of the report shall be considered as "Breach of Contract" and shall attract punitive actions as per the relevant provisions of the Contract including non-release of subsidy. However, the decision of Engineer-in -charge shall be final in this regard.

1. SOLAR PANELS

- The panels are to be cleaned at least once every fifteen days.
- Any bird droppings or spots should be cleaned immediately.
- Use water and a soft sponge or cloth for cleaning.
- Do not use detergent or any abrasive material for panel cleaning.
- Iso-propyl alcohol may be used to remove oil or grease stains.
- Do not spray water on the panel if the panel glass is cracked or the back side is perforated.
- Wipe water from module as soon as possible.
- Use proper safety belts while cleaning modules at inclined roofs etc.
- The modules should not be cleaned when they are excessively hot. Early morning is particularly good time for module cleaning?
- Check if there are any shade problems due to vegetation or new building. If there are, make arrangements for removing the vegetation or moving the panels to a shade-free place.
- Ensure that the module terminal connections are not exposed while cleaning; this poses a risk of electric shock.
- Never use panels for any unintended use, e. g. drying clothes, chips etc.
- Ensure that monkeys or other animals do not damage the panels.

2. CABLES AND CONNECTION BOXES

- Check the connections for corrosion and tightness.
- Check the connection box to make sure that the wires are tight, and the water seals are not damaged.
- There should be no vermin inside the box.
- Check the cable insulating sheath for cracks, breaks or burns. If the insulation is damaged, replace the wire.
- If the wire is outside the building, use wire with weather-resistant insulation.
- Make sure that the wire is clamped properly and that it should not rub against any sharp edges or corners.
- If some wire needs to be changed, make sure it is of proper rating and type.

3. INVERTER

- The inverter should be installed in a clean, dry, and ventilated area which is separated from, and not directly above, the battery bank.
- Remove any excess dust in heat sinks and ventilations. This should only be done with a dry cloth or brush.
- Check that vermin have not infested the inverter. Typical signs of this include spider webs on ventilation grills or wasps' nests in heat sinks.
- Check functionality, e.g. automatic disconnection upon loss of grid power supply, at least once a month.
- Verify the state of DC/AC surge arrestors, cable connections, and circuit breakers.

4. SHUTTING DOWN THE SYSTEM

- Disconnect system from all power sources in accordance with instructions for all other components used in the system.
- Completely cover system modules with an opaque material to prevent electricity from being generated while disconnecting conductors.
- To the extent possible, system shutdown will not be done during day time or peak generation.

INSPECTION AND MAINTENANCE SCHEDULE

Component	Activity	Description	Interval	By
PV Module	Cleaning	Clean of bird droppings/dark spots on modules.	Immediately	User/ Technician
	Cleaning	Clean PV modules with plain water or mild dish washing detergent. Do not use brushes, any type of solvents, abrasive, or harsh detergents.	Fortnightly or as per the site conditions.	User/ Technician
	Inspections for plants >100 KWp	Use infrared camera to inspect for hot spots; bypass diode failure	Annual	Technician

Component	Activity	Description	Interval	By
PV Array	Inspection	Check PV Module and rack for any damage note down location and serial no. of damaged modules	Annual	User/ Technician
	Inspection	Determine if any new object such as a vegetation growth are causing shading of the array and move them if possible.	Annual	User/ Technician
	Vermin removal	Remove bird nests or vermin from array and rack area	Annual	User/ Technician
Junction Boxes	Inspection	Inspect electrical boxes for corrosion or intrusion of water or insects. Seal boxes is required. Check position of switches and breakers. Check operation of all protection devices.	Annual	Electrician
Wiring	Inspection	Inspect cabling for signs of cracks, defects, loose connections, overheating, arching, short or open circuits, and ground faults.	Annual	Electrician
Inverter	Inspection	Observe	Monthly	Electrician

ANNEXURE –“A”**Monthly Comprehensive Maintenance Report Format****Month and year:****Name of the System Integrator:****Project Capacity:****Address of the site:**

Part A *Provide details of any replacement of systems/components, damages, plant/inverter shut down (planned/forced), breakdown, etc under remarks.

*Register is to be maintained by the system integrator at each location where solar power plant of all the sites mentioned in this bid. The same may be inspected by CREDA or its authorized representative at any time during 5 years of Comprehensive Maintenance period. The Register will have the information about the generation, Inverter downtime if any, Grid outages etc.

ANNEXURE –“A”-I

Monthly Comprehensive Maintenance Report

Month and year:

Name of the System Integrator:

Project:

Capacity:

Name of the site:

PART-A

Component	Activity	Description	Date	Name / Signature	*Remarks
PV Module	Cleaning	Immediately clean any bird droppings/ dark spots on module.			
	Cleaning	Clean PV modules with plain water or mild dishwashing detergent.			
	Inspection (for plants > 100 kWp)	Infrared camera inspection for hot spots; bypass diode failure.			
PV Array	Inspection	Check the PV modules and rack for any damage.			
	Inspection	If any new objects, Such as vegetation growth etc., are causing shading of the array. Remove if any.			
	Vermin Removal	Remove bird nests or Vermin from array and rack area.			
Junction Boxes	Inspection	<input type="checkbox"/> Inspect electrical boxes for corrosion, intrusion of water or vermin. <input type="checkbox"/> Check position of switches and Breakers. <input type="checkbox"/> Check status of all protection devices.			
Wiring	Inspection	Inspect cabling for signs of cracks, defects, loose connections, corrosion,			

Component	Activity	Description	Date	Name / Signature	*Remarks
		overheating, arcing, Short or open circuits and ground faults.			
Inverter	Inspection	<input type="checkbox"/> Observe instantaneous operational indicators on the faceplate. <input type="checkbox"/> Inspect Inverter housing or shelter for Any physical maintenance. <input type="checkbox"/> Check for connection tightness.			
Inverter	Service	Clean or replace any air filters.			
Instruments	Validation	Verify monitoring Instruments (pyranometer etc.) with standard instruments to verify their operation within tolerance limits.			
Transformer	Inspection	Inspect transformer oil level, temperature gauges, breather, silica gel, meter, connections etc.			
Plant	Monitoring	Daily Operation and Performance Monitoring.			
Spare Part	Management	Manage inventory of Spare Part.			
Log Book	Documentation	Maintain daily log Records.			
Tracker (if any)	Inspection	Inspect gears, gear Boxes, bearings, motors.			
	Service	Lubricate bearings, gear as required.			

*Provide details of any replacement of systems/components, damages, plant/inverter shut down (planned/forced), breakdown, etc under remarks.

*Daily register is to be maintained by the bidder at each location greater than 10kWp. The same may be inspected by CREDA or its authorized representative at any time 5 years of Comprehensive Maintenance period. The Register will have the information about the daily generation, Inverter downtime if any, Grid outages.

ANNEXURE –“A”-II

Part B

Date of Month	Generation in KWh	Grid outage (hh:mm)	Inverter down period (hh:mm)	Remarks
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				
26				
27				
28				
29				
30				
31				

Total generation for the month in kWh:

Cumulative generation since commissioning in kWh:

CUF for month in %:

Cumulative CUF since commissioning in %:

Date:

(Name:_____)

Signature of the Authorized signatory of the System Integrator

(Name:_____)

Signature of the Authorized signatory of the Beneficiary

Format for Solar Generation Reading

Table[i]					
Solar Generation					
S.No.	Previous Month reading	Current Month Reading	Total Reading(3-2)	MF	Total Generation KWh (A)= (4*5)
1	2	3	4	5	6
Table[j]					
Solar Power Exported to CSPDCL Grid					
S.No.	Previous Month reading	Current Month Reading	Total Reading(3-2)	MF	Total export power in KWh (B)=(4*5)
1	2	3	4	5	6
Table[k]					
Power Imported from CSPDCL Grid					
S.No.	Previous Month reading	Current Month Reading	Total Reading(3-2)	MF	Total import power in KWh (C)=(4*5)
1	2	3	4	5	6

Exported KWh% of Total Generation (B/A)*100:-

Solar Power Utilized by Beneficiary in KWh (A-B) :-

% of Solar Power Utilized by Beneficiary [(A-B)/A]*100:-

Total Power Consumption of Beneficiary (A-B+C):-

Remark if any

SECTION – 5

1.e-Price Bid

Schedule of Rates for SPV Power Plant Systems

As per Specifications & Scope of Work of BID DOCUMENT No.82244 /CREDA/HOR/RE-V/GCRT/2021-22 dated.27.08.2021

Design, Manufacturing, Supply, Erection, Testing & Commissioning & Maintenance for a period of 5 years including Power Evacuation System and cost of replacement of all the Part, covered under Guarantee period for a period of 5 years from the date of commissioning of Roof top Solar PV system.

S N	Item Code	Description	UOM	Qua- ntity	Cost of Supply of system (INR excl of GST)	Appli cable GST (5%)	Total Cost of Supply of system (INR incl of GST)	Cost of Installati on and Commis sioning (INR excl of GST)	Appli cable GST (18%)	Total Cost of Installati on and Commis sioning (INR incl of GST)	Cost of 5years Main- tenance (INR excl. GST)*	Applic able GST (18%)	Cost of 5 years Mainte nance (INR incl GST)	Total Project Cost inclusive of GST (INR)**
1	Cost for total 200 KWp on-grid SPVPP	Sihawa & Mahamaya Bhawan Building in Pt. Sunder Lal Sharma Open University, Birkona, Bilaspur.	L U M S U M	1										
2	Cost for total 30 KWp on-grid SPVPP	Old buidling District & Session Court, Raigarh.	L U M S U M	1										
3	Cost for total 20 KWp on-grid SPVPP	New buidling District & Session Court, Raigarh.	L U M S U M	1										

Note:-*CMC price must not be less than 8% of Total Project Cost (inclusive of GST)

****L1 bidder would be compared based on the Total project cost mentioned in last Column.**

Name of the authorized Signatory:

Signature of the Authorized Signatory:

Seal of Company:

Date:

ANNEXURE-I

2. DRAFT AGREEMENT

Agreement

This agreement is hereby made today the at Raipur between M/s, a company / firm registered under the Companies Act, 1956 / Partnership Act / Act, having its registered office at(here in after called as “Bidder”, the term which includes its successors, assigns and legal heirs), through Mr/Mrs., resident of duly authorized for execution of this agreement on one hand and Chhattisgarh State Renewable Energy Development Agency (CREDA) registered under Societies Act having its Registered office at VIP Road Airport Road (hereinafter called as “CREDA” the term which includes its successors, assigns and legal heirs) on the other hand on the following terms and conditions:-

01. Whereas, the “CREDA” had floated Tender No. for **Design, Supply, Installation & Commissioning of Solar Photovoltaic Power Plants With Five Years Maintenance of Grid Connected Solar Power Plant of CapacityKWp at** (here in after called as “Work”) and “Contractor” had submitted their rates and agreed to supply/perform the “Work” to CREDA on the rates as stated below (here in called rate) as per the terms and conditions of the tender and its corrigendum already agreed upon, and,

S.No.	Work Details	Total Cost inclusive of GST
1	Design, Supply, Installation & Commissioning of Grid Connected Solar Photo Voltaic Power Plant CapacityKWp	
2	Five Years Comprehensive Maintenance	
Total (Inclusive of all taxes)		
Rs		
(Actual GST Shall be applicable as per Norms of GST Council as Notified.)		

02. The following terms of payment shall apply: -

- 97% of the eligible payment as per the work order (excluding the cost of Comprehensive Maintenance) after satisfactory supply, installation, commissioning & after satisfactory synchronization & generation report of minimum one month from the date of synchronization & performance evaluation of the system at site with proper handing over and fulfilling following conditions
 - i) Copy of (MOM) Minutes of Metering duly signed by authorized officials at the time of Grid synchronization.
 - ii) Receipt of Copy of Grid Connectivity Approval from the Concern Divisional Office of CSPDCL.
 - iii) Installation of water pipe line for cleaning of Solar Modules as per approval of CREDA.
 - iv) Generation report of minimum one month from the date of synchronization verified by concern CREDA’s Regional Office.
- Balance 3% payment (without GST) shall be retained by CREDA as performance security for a period of 60 Months from the date of commissioning.

Continued on next page

//2//

- 03 After successful Commissioning/ Synchronization payment of Comprehensive Maintenance shall be released.
- On receipt of Comprehensive maintenance report as per scope of work through concern District & Regional office to SPV Grid Connected Cell of HO, CREDA on monthly basis. Payment would be done on quarterly basis as per rate quoted for next five years from the date of commissioning of SPV Power plant. Date of Synchronization of installed power plant shall be considered as date of Commissioning of plant.
04. Rest of the terms & conditions of the bid would be applicable.
05. Whereas, the rates quoted by the “Contractor” are inclusive of GST & all taxes, duties, levies, transport and all other incidental expenses F.O.R. at site and no escalation on rate and additional payment shall not be made.
06. On placement of order by CREDA, the Contractor shall execute the work as per the terms, conditions & specifications, scope of work, etc. of the Tender.
07. Whereas, the “Contractor” is committed to execute the “ Work “ at the ordered site, on the rates already agreed upon, within the schedule mentioned in the Work/Supply order.
08. The Contractor shall have to complete the work as per the terms and conditions of the Tender and Scope of Work and submit the reports within the time frame as stated in the Tender. If the completion of work is delayed due to any reason beyond the control of the Contractor, the Contractor shall, without delay, give notice to CREDA in writing of his claim for an extension of time. CREDA, on receipt of such notice may agree to extend the contract imposing penalty clause of the Tender, on merits; however if no notice is given by the Contractor or no valid reason for delay of work, then the contract shall be deemed to be cancelled/penalized.
09. Whereas, it has been also agreed upon that the contractor shall provide unconditional onsite warrantee for any manufacturing defects within stipulated time limits as per terms of the tender, for modules 10 years and for inverter and BOS 5 years failing which CREDA shall have liberty to replace the defective material or to carry out repairs if any at the cost of contractor.
10. Whereas, it has been also agreed upon that the contractor shall provide details of the taxes applicable for the material and works duly certified by chartered accountant against the contract awarded to them whenever asked by CREDA. Failing which in case of any discrepancy/ Tax liability is found the contractor will be solely responsible for the same.
11. Whereas, it is agreed upon that all the terms and conditions of the tender with its Corrigendum and work/ supply orders which have already been agreed upon shall form part of this agreement, and,
12. It is also agreed that, if any sub contractor/Vendor/Staff/ laborer is engaged for the allotted work the payment liabilities for them should be of contractor, if they fail to do the same, then the payment will be made by CREDA on contractor cost.
13. It is also agreed that the contractor shall ensure all safety measures for carrying out ordered work. He will also ensure insurance of workers and materials for the assigned work and will also ensure compliance of all relevant Acts and Policies e.g. Indian Electricity Act, Safety Act, Workmen compensation Act etc, failing which in case of any accident/ incident liability is found, the contractor will be solely responsible for the same.
14. Whereas it has been also agreed that Comprehensive Maintenance (CM) of SPV Power Plant would include wear and tear, overhauling breakdown insurance and replacement of defective modules inverters, spares consumables etc. for period of five years. Contractor shall be responsible for all the required activities for successful operation & Maintenance of SPVPP for the period of five years from the date of connectivity. Maintenance activities shall be strictly followed as per tender and required to submit Comprehensive maintenance report on monthly basis as per annexure "A" (Part A & B) (attached).

Continued on next page

//3//

15. Whereas, it has been also agreed upon that during any disputes regarding interpretation of any of the clauses of this agreement, the decision of the “Chief Executive Officer, CREDA” shall be final and binding on both the parties,
16. Whereas, it has also been agreed that for any disputes arising, the jurisdiction shall be the Courts of Raipur,
17. Whereas, it has also been agreed that scope of work, technical specification, payment terms, Maintenance procedure as per tender.

In witness whereof, both the parties thereto, put their signatures below:-

Signed & Sealed on behalf of the above
Name -
Designation –

Signed on behalf of CREDA
Name -
Designation - Chief Engineer

Witness: -

Witness:-

01-Name : -

02- Name : -

Address :-.....

Address :-.....

.....

.....

3. SCHEDULE - I

PART 'A': GENERAL INFORMATION

(Strike off whichever is not applicable. Separate sheets should be used, wherever necessary)

01. Name & Address of the Bidder :
02. Name & Address of the firm/Company etc. :
 - a) Registered office :
 - b) Factory/works address :
 - c) Fax Nos. :
 - d) Telephone / Mobile Nos. :
 - e) Email id :
03. Confirm whether Bidder is Manufacturer : Yes/No
04. Only manufacturer to give following particulars
 - a) Address of factory :
 - b) Year of starting manufacture :
 - c) Whether same/similar materials Manufactured earlier (if yes, give reference) :
 - d) Yearly/monthly production capacity :
 - e) Maximum yearly production Achieved so far :
05. Whether the firm is SSI Unit of Chhattisgarh State: Yes/No
 - a) If yes, write registration No. :
 - b) Whether documentary evidence Regarding registration enclosed :
 - c) Items for registration :
 - d) Period of registration :
 - d) Whether latest copy Competency/ Certificate furnished : Yes/No
06. Whether the firm is 100% owned by
 - a) State Government : Yes/No
 - b) Central Government : Yes/No
 - If yes, Notification/certificate issued from : Yes/No
 - The competent authority to this effect is Enclosed
07. a) Whether the bidder is old participant with CREDA : Yes/No
 - b) If yes, whether documentary Evidence is enclosed. : Yes/No
08. Any other information that bidder may like to give in order to highlight his bid : If yes, give details

PLACE:

SIGNATURE OF BIDDER

NAME IN FULL

DATE:

DESIGNATION/STATUS

FIRM/COMPANY SEAL

4. SCHEDULE - II

PART 'B': COMMERCIAL INFORMATION

(Strike off, whichever is not applicable. Separate sheets should be used. Wherever necessary)

- | | | |
|---|---|--------------------------------------|
| 01. (i) Earnest Money Details | : | RTGS/NEFT payable to "CREDA", Raipur |
| (ii) Amount of E.M.D. & full details | : | ₹. |
| | | |
| 02. Whether the offer is valid for 6 months from the date of opening of commercial/technical bid. | : | Yes/No |
| 03. Rate of Sales Tax on the date of bid (exclusive in the rate quoted) | : | |
| 04. DISCOUNT: | | |
| a) Whether any rebate/discount is offered. | : | Yes/No |
| b) If yes, whether the rebate is unconditional/conditional :
Rate/amount of rebate/discount | : | Yes/No |
| c) If conditional State condition | : | Yes/No |
| 05. PAYMENT TERMS:
Whether CREDA's terms of payment is acceptable to Bidder | | |
| 06. COMPLETION PERIOD OF WORK:
Whether Bidder is agreeing for completion period of work as Specified in the Bid | : | Yes/No |
| 07. PENALTY CLAUSE:
Whether agreeable to CREDA's Penalty Clause | | |
| 08. Whether agreeable to CREDA's clause of warrantee period : | : | Yes/No |
| 09. SECURITY DEPOSIT:
Whether Security Deposit clause is understood | | |
| 10. Indicate State, Central Sales Tax Registration Number | : | Yes/No |
| Central: | | |
| (Please Note that in case of non-registration with Commercial Tax, Department Purchase Tax as admissible shall be deducted by the Purchaser from the Bills of the supplier) | | |
| 11. Please mention whether rates offered are applicable for part quantities. | : | Yes/No |

PLACE:

SIGNATURE OF BIDDER

DATE:

NAME IN FULL

DESIGNATION/STATUS

FIRM/COMPANY SEAL

5. SCHEDULE - III

PART 'C': TECHNICAL INFORMATION

(Strike off whichever is not applicable. Separate sheets should be used. Wherever necessary)

- | | | | |
|------------|--|---|----------------------------------|
| 01. | Whether material offered is exactly as per technical specification | : | Yes/No |
| 02. | Whether the copies of completion certificate received during last 3 years from other State Nodal Agency or from other Organization for Grid Connected Rooftop solar Power Plants (if yes, give details) enclosed. | : | Yes/No |
| 03. | Whether pamphlets/technical details literatures along with drawing etc. furnished with the offer | : | Yes/No
(if yes, give details) |
| 04. | Whether the Bidder agrees to furnish material test certificates in respect of chemical composition and physical properties from Govt./ Govt. approved lab with each batch of supplies. | : | Yes/No |
| 05. | Whether the Bidder has furnished details of manufacturing equipments and short history of plant | : | Yes/No
(if yes, give details) |
| 06. | Whether details of manufacturing process furnished with offer. | : | Yes/No
(If yes, give details) |
| 07. | a) Whether all testing facilities are available.
If so, give details and in case of non-availability of facilities indicate approved lab available in surrounding areas where tests are proposed to be conducted. | : | Yes/No |

PLACE

SIGNATURE OF BIDDER

DATE

NAME IN FULL

DESIGNATION/STATUS

FIRM/COMPANY

SEAL

6. ANNEXURE – II

FORMAT FOR THE AFFIDAVIT

(Note: This affidavit should be on a non-judicial stamp paper of Rs. 100/- and shall be attested by Magistrate/Sub-Judge/ Notary Public)

I,.....(Name of the bidder authorized representative of the bidder) son/ daughter of..... resident of (Full address), aforesaid solemnly affirm and state as under:

1. I hereby certify that all the information furnished with the bid submitted in response to Tender/bid no.82244/HOR/RE-V/GCRT/2021-22 DT.27-08-2021 issued by Chhattisgarh State Renewable Energy Development Agency (CREDA) (authority inviting bids) for Design, Supply, Installation and Commissioning with 5 years comprehensive maintenance of Grid Connected Solar Photovoltaic Power Plant of different capacities at two different locations in Chhattisgarh state (name and identification of work) are true and correct.
2. I hereby certify that I have been authorized by..... (Company name) to sign on their behalf, the bid mentioned in Sr.No.1 above.*
3. Information furnished in the bidding documents is correct in all respects to the best of my knowledge and belief.
4. The near relations, as per clause 30(A) in Section - 02, in CREDA, are not in employment of the firm/company. (Note:-By the term near relatives is meant Wife, Husband, Parents and Son, Brother, Sister, Brother-in-law, Father-in-law, Mother-in-law etc.) (if working mention the name/names)
.....
.....
5. The name of near relative (if any) as per Clause 31(B) who retired/removed within the last two years. (If None, clearly State None)
.....
.....
6. No near relative is working as Financial Accountant in the CREDA. (if working mention the name)
.....
.....
7. No person is working in the company in any capacity, who are near relatives to any Officer in Chhattisgarh State Renewable Energy Development Agency (CREDA) (If working mention the name)
.....
.....

1. Our company/firm/ or otherwise is not under the clarification of ineligibility for corrupt and fraudulent practices by the Central Government, the State Government or any public undertaking, autonomous body, authority by whatever name called under the Central or the State Government as mention in clause 1(F) of tender document.
2. I hereby authorize the CREDA Officials to get all the documents verified from appropriate sources (s).

Deponent

Place:

Date:

* Not applicable if the bidder is an individual and is signing the bid on his own behalf.

Verification

I..... S/o.....do here by affirm that contents stated in Para 1 to 09 above and contents submitted in technical & financial bid are true to the best of my knowledge and believe and are based on my/our record.

Verified that this date of at (Place).....

Deponent

7. ANNEXURE – III

Benchmark Cost

As per Ministry of New & Renewable Energy (MNRE) Benchmark Costs for Grid-connected Rooftop Solar Photo-voltaic systems of various capacities.

S.No.	Capacity Range	Benchmark Costs (Rs. per Watt)
1	>10 to 100 kW	38
2	>100 to 500 kW	36

All the above benchmark costs are inclusive of total system cost including Photo-Voltaic solar modules, invertors, balance of systems including cables, Switches/Circuit Breakers/Connectors/Junction boxes, mounting structure, earthing, Lightening arrestor, cost of meters, local connectivity cost, cost of civil works, foundation etc. and its installation, commissioning, transportation, insurance, capital cost of online monitoring, comprehensive maintenance charges for five years, applicable fees and taxes etc.

8. ANNEXURE- IV

UNDERTAKING FROM SYSTEM INTEGRATOR FOR REGISTRATION

1. It is hereby certified that my firm..... is registered with CREDA as System Integrator under Category B/C.

Seal and Signature of Authorized Signatory.

OR

We hereby submit our undertaking that

2. Presently we are not registered with CREDA as System Integrator under Category “B” or “C”

And

3. We have read and understood all the terms and conditions of CREDA registration

And

4. Accordingly we meet all the eligibility criteria of registration as System Integrator in 2021-22.

And

5. We shall get registered as System Integrator under Category “B” or “C” if we are the lowest bidder in.....

And

6. If we are not found eligible for registration as System Integrators CREDA may forfeit our EMD.

Seal and signature of authorized signatory.

Name of the Firm

Date:-