

CORRIGENDUM-1

Ref: 1. Tender No.: 198460/CREDA/Repair & Maintenance /2026-27 Dated: 03-09-2026

**Following Amendment/Addendum/Clarification is being made against Tender No.: 198460/CREDA/Repair & Maintenance /2026-27
Dated: 03-09-2026**

S. No.	Page No./ Ref. Clause	Original Version	Amendment/Addendum/Clarification Version
1	Sec-5 /Page No. 29/	The “Motor Pump Set” should following features: The DC pump set with the impeller mounted directly on the motor shaft and with appropriate mechanical seals, which ensures zero leakage.	The “Motor Pump Set” should following features: - The DC Pump set shall be of suitable construction, such as shaft-mounted or submersible type, with a suitable sealing arrangement/fully sealed construction to prevent leakage and ensure reliable and maintenance-free operation. The pump shall comply with the specified head, discharge, efficiency, power and other applicable technical requirements.
2	E-price bid/ Page No. 39/	Items Description- Supply of GI Stand Posts (304 grades) (Square 150 mm x 150 mm of height 0.8 M above GL) for SPV Dual Pump with 04 nos. 20 mm stainless steel lift- cock type as per Specifications of MNRE/CREDA.	Supply of GI Stand Posts or 304 grade steel (Square 150 mm x 150 mm of height 0.8 M above GL) for SPV Dual Pump with 04 nos. 20 mm stainless steel lift- cock type as per Specifications of MNRE/CREDA.
3	Section-06 page no 34	Pump category-Water Filled	Pump category -Water Filled/Oil Filled
4	Section 05 page no 29 Frequency	Pump controller for DC submersible pump of Capacity 0.5/1/1.5/2 HP-Frequency 0-110 Hz	Pump controller for DC submersible pump of Capacity 0.5/1/1.5/2 HP-Frequency 0-110Hz minimum, Extended up to 300Hz or higher acceptable

Continued...

Revised Schedule:

Particulars	From Date & Time	To Date & Time	Place
Display of Sample and Inspection of Sample by Tender Committee	17.09.2026 12:00PM	17.09.2026 02:00PM	At CREDA H.O., Conference Hall, Raipur.
Submission of Online Bid (Technical + e-Price Bid)	03.09.2026 05:00 PM	01.10.2026 05:00 PM	https://eproc.cgstate.gov.in and Hard Copy at CREDA H.O., Conference Hall, Raipur.
Opening of Technical Bid	05.10.2026 12:00 PM Onwards		At CREDA H.O., Conference Hall, Raipur.
Evaluation of Technical bid	06.10.2026 12:00 PM Onwards		At CREDA H.O., Conference Hall, Raipur.
Opening of e- Price Bid	07.10.2026 12:00 PM Onwards		At CREDA H.O., Conference Hall, Raipur.

Note-

- All above amendments will be applicable for every clause having same point (co-related) in tender document.
- All other terms and conditions will remain same as per tender document.
- Bidder shall take note of the above amendment.
- This amendment form is an integral part of bidding document and shall be submitted along with the e-technical bid duly stamped and signed as a token of acceptance.


Chief Engineer
CREDA HO Raipur