

//CORRIGENDUM (Amendment) For T. No. 81347, dated 07-09-2021//

In continuation of Tender No. 81347, dated 07-09-2021 for supply of various fabrication items used in power distribution works (PDN) for operation and maintenance/new project works of solar power plant installed by CREDA anywhere in the state of Chhattisgarh.

As per discussion by CREDA's Tender Committee certain amendments have been made in the tender conditions as below:-

SN	ClauseNo.	Tender Clause	Amended Clause and Remarks (if any)
1	Page no. 41, Price Bid, point no. 6	<p>Fabrication and supply of M.S. Pole, with ISI "B" Class M.S. Pipe as per drawing and specification enclosed with all material and with two coat Zink Chromate primer and tow coat Silver/Aluminium Paint of standard brand 12" x 12" base plate (10 mm thickness) foundation in MS Pole with stiffener and 4 Nos. T-bolt with double nuts (20 mm. Dia & 900 mm. Length. Nut bolt arrangement in 4 feet from the bottom of pole.</p> <p>A 6.1 - 5.7 Meter Height Approx Min Weight 40-42 kg bare pole</p> <p>A 6.2 - 7.5 Meter Height Approx Min Weight 80-82 kg bare pole</p>	<p>Fabrication and supply of M.S. Pole, with ISI "B" Class M.S. Pipe as per drawing and specification enclosed with all material and with two coat Zink Chromate primer and tow coat Silver/Aluminium Paint of standard brand <u>225 mm x 225 mm base plate (8 mm thickness)</u> foundation in MS Pole with stiffener and 4 Nos. T-bolt with double nuts (20 mm. Dia & 900 mm. Length. Nut bolt arrangement in 4 feet from the bottom of pole.</p> <p>A 6.1 - 5.7 Meter Height Approx Min Weight <u>45-48</u> kg bare pole</p> <p>A 6.2 - 7.5 Meter Height Approx Min Weight <u>57-60</u> kg bare pole</p>

Note:-

- All above amendments shall be applicable for every clause having same point co-related in the tender document.
- All other terms & conditions shall remain same as per the tender document.

(Sanjeev Jain)

Chief Engineer (RE-V)